

Отчет о суточных параметрах
(01.05.2023 0:00:00 - 31.05.2023 0:00:00)

Объект: Пермь г, Анвара Гатауллина ул, д. 13 (1.2 МКД (УК ПрофКом) 2эт.)

Прибор: ВКТ-7 Заводской номер: 111782

Точка измерения: ТВ1; Ресурс: ТС

Схема измерений: Закрытая система отопления, дополнительный канал измерения расхода по тр3 (Схема 3)

Дата	t1	t2	dt	V1	V2	V3	%	M1	M2	%	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3	м3		Т	Т		Т	кг/см2	кг/см2	Гкал	ч	ч	
01.05.2023	20.09	---	---	0.00	0.42	0.00	-200.00	---	---	---	---	0.00	0.00	---	0.0	24.0	*
02.05.2023	19.71	---	---	0.00	0.41	0.00	-200.00	---	---	---	---	0.00	0.00	---	0.0	24.0	*
03.05.2023	20.15	---	---	0.00	0.42	0.00	-200.00	---	---	---	---	0.00	0.00	---	0.0	24.0	*
04.05.2023	20.48	---	---	0.00	0.42	0.00	-200.00	---	---	---	---	0.00	0.00	---	0.0	24.0	*
05.05.2023	20.50	---	---	0.00	0.42	0.00	-200.00	---	---	---	---	0.00	0.00	---	0.0	24.0	*
06.05.2023	20.30	---	---	0.00	0.42	0.00	-200.00	---	---	---	---	0.00	0.00	---	0.0	24.0	*
07.05.2023	19.73	---	---	0.00	0.42	0.00	-200.00	---	---	---	---	0.00	0.00	---	0.0	24.0	*
08.05.2023	18.13	---	---	0.00	0.38	0.00	-200.00	---	---	---	---	0.00	0.00	---	0.0	24.0	*
09.05.2023	17.04	---	---	0.00	0.37	0.00	-200.00	---	---	---	---	0.00	0.00	---	0.0	24.0	*
10.05.2023	16.93	---	---	0.00	0.36	0.00	-200.00	---	---	---	---	0.00	0.00	---	0.0	24.0	*
11.05.2023	17.17	---	---	0.00	0.37	0.00	-200.00	---	---	---	---	0.00	0.00	---	0.0	24.0	*
12.05.2023	17.30	---	---	0.00	0.37	0.00	-200.00	---	---	---	---	0.00	0.00	---	0.0	24.0	*
13.05.2023	17.68	---	---	0.00	0.37	0.00	-200.00	---	---	---	---	0.00	0.00	---	0.0	24.0	*
14.05.2023	17.92	---	---	0.00	0.38	0.00	-200.00	---	---	---	---	0.00	0.00	---	0.0	24.0	*
15.05.2023	17.97	---	---	0.00	0.38	0.00	-200.00	---	---	---	---	0.00	0.00	---	0.0	24.0	*
16.05.2023	17.97	---	---	0.02	0.39	0.00	-180.49	---	---	---	---	0.00	0.00	---	0.0	24.0	*
17.05.2023	17.99	---	---	0.00	0.36	0.00	-200.00	---	---	---	---	0.00	0.00	---	0.0	24.0	*
18.05.2023	18.28	17.65	0.63	0.00	0.37	0.00	-200.00	0.00	0.32	-200.00	-0.32	0.00	0.00	0.000	20.0	4.0	*
19.05.2023	18.97	18.69	0.28	0.00	0.42	0.00	-200.00	0.00	0.42	-200.00	-0.42	0.00	0.00	0.000	24.0	0.0	*
20.05.2023	19.10	18.89	0.21	0.00	0.41	0.00	-200.00	0.00	0.41	-200.00	-0.41	0.00	0.00	0.000	24.0	0.0	*
21.05.2023	19.46	19.14	0.32	0.00	0.41	0.00	-200.00	0.00	0.41	-200.00	-0.41	0.00	0.00	0.000	24.0	0.0	*
22.05.2023	20.03	19.63	0.40	0.00	0.42	0.00	-200.00	0.00	0.42	-200.00	-0.42	0.00	0.00	0.000	24.0	0.0	*
23.05.2023	20.46	20.01	0.45	0.00	0.41	0.00	-200.00	0.00	0.41	-200.00	-0.41	0.00	0.00	0.000	24.0	0.0	*
24.05.2023	20.78	20.26	0.52	0.00	0.41	0.00	-200.00	0.00	0.41	-200.00	-0.41	0.00	0.00	0.000	24.0	0.0	*
25.05.2023	21.04	20.46	0.58	0.00	0.42	0.00	-200.00	0.00	0.42	-200.00	-0.42	0.00	0.00	0.000	24.0	0.0	*
26.05.2023	21.35	20.69	0.66	0.00	0.42	0.00	-200.00	0.00	0.42	-200.00	-0.42	0.00	0.00	0.000	24.0	0.0	*
27.05.2023	21.74	20.99	0.75	0.00	0.42	0.00	-200.00	0.00	0.42	-200.00	-0.42	0.00	0.00	0.000	24.0	0.0	*
28.05.2023	21.90	21.04	0.86	0.00	0.42	0.00	-200.00	0.00	0.42	-200.00	-0.42	0.00	0.00	0.000	24.0	0.0	*
29.05.2023	22.17	21.30	0.87	0.00	0.42	0.00	-200.00	0.00	0.42	-200.00	-0.42	0.00	0.00	0.000	24.0	0.0	*
30.05.2023	22.20	21.50	0.70	0.00	0.43	0.00	-200.00	0.00	0.43	-200.00	-0.43	0.00	0.00	0.000	24.0	0.0	*
31.05.2023	22.34	21.56	0.78	0.00	0.42	0.00	-200.00	0.00	0.42	-200.00	-0.42	0.00	0.00	0.000	24.0	0.0	*
Средние:	19.58	20.13	0.57	---	---	---	-199.37	---	---	-200.00	---	0.00	0.00	---	---	---	---
Итого:	---	---	---	0.02	12.46	0.00	---	0.00	5.75	---	-5.75	---	---	0.000	332.0	412.0	

Дата	V1	V2	V3	M1	M2	Mг	Qo	ВНР	ВОС
	м3	м3	м3	Т	Т	Т	Гкал	ч	ч
30.04.2023	4740.36	4689.74	0.00	4575.95	4606.31	-30.36	150.543	3656.0	123.0
31.05.2023	4740.38	4702.20	0.00	4575.95	4612.06	-36.11	150.543	3988.0	535.0
Итого:	0.02	12.46	0.00	0.00	5.75	-5.75	0.000	332.0	412.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах
(01.06.2023 0:00:00 - 30.06.2023 0:00:00)

Объект: Пермь г, Анвара Гатауллина ул, д. 13 (1.2 МКД (УК ПрофКом) 2эт.)

Прибор: ВКТ-7 Заводской номер: 111782

Точка измерения: ТВ1; Ресурс: ТС

Схема измерений: Закрытая система отопления, дополнительный канал измерения расхода по тр3 (Схема 3)

Дата	t1	t2	dt	V1	V2	V3	%	M1	M2	%	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3	м3		т	т		т	кг/см2	кг/см2	Гкал	ч	ч	
01.06.2023	22.47	21.68	0.79	0.00	0.42	0.00	-200.00	0.00	0.42	-200.00	-0.42	0.00	0.00	0.000	24.0	0.0	*
02.06.2023	22.63	21.93	0.70	0.00	0.43	0.00	-200.00	0.00	0.43	-200.00	-0.43	0.00	0.00	0.000	24.0	0.0	*
03.06.2023	22.75	22.00	0.75	0.00	0.42	0.00	-200.00	0.00	0.42	-200.00	-0.42	0.00	0.00	0.000	24.0	0.0	*
04.06.2023	22.80	22.07	0.73	0.00	0.42	0.00	-200.00	0.00	0.42	-200.00	-0.42	0.00	0.00	0.000	24.0	0.0	*
05.06.2023	22.48	21.91	0.57	0.00	0.42	0.00	-200.00	0.00	0.42	-200.00	-0.42	0.00	0.00	0.000	24.0	0.0	*
06.06.2023	22.02	21.49	0.53	0.00	0.42	0.00	-200.00	0.00	0.42	-200.00	-0.42	0.00	0.00	0.000	24.0	0.0	*
07.06.2023	21.67	21.24	0.43	0.00	0.42	0.00	-200.00	0.00	0.42	-200.00	-0.42	0.00	0.00	0.000	24.0	0.0	*
08.06.2023	21.37	21.06	0.31	0.00	0.42	0.00	-200.00	0.00	0.42	-200.00	-0.42	0.00	0.00	0.000	24.0	0.0	*
09.06.2023	20.76	20.49	0.27	0.00	0.42	0.00	-200.00	0.00	0.42	-200.00	-0.42	0.00	0.00	0.000	24.0	0.0	*
10.06.2023	20.52	20.26	0.26	0.00	0.42	0.00	-200.00	0.00	0.42	-200.00	-0.42	0.00	0.00	0.000	24.0	0.0	*
11.06.2023	19.95	19.80	0.15	0.00	0.42	0.00	-200.00	0.00	0.42	-200.00	-0.42	0.00	0.00	0.000	24.0	0.0	*
12.06.2023	19.63	19.62	0.01	0.00	0.42	0.00	-200.00	0.00	0.42	-200.00	-0.42	0.00	0.00	0.000	24.0	0.0	*
13.06.2023	19.35	19.34	0.01	0.00	0.42	0.00	-200.00	0.00	0.42	-200.00	-0.42	0.00	0.00	0.000	24.0	0.0	*
14.06.2023	19.60	19.54	0.06	0.00	0.42	0.00	-200.00	0.00	0.42	-200.00	-0.42	0.00	0.00	0.000	24.0	0.0	*
15.06.2023	20.03	19.91	0.12	0.00	0.42	0.00	-200.00	0.00	0.42	-200.00	-0.42	0.00	0.00	0.000	24.0	0.0	*
16.06.2023	20.15	20.02	0.13	0.00	0.42	0.00	-200.00	0.00	0.42	-200.00	-0.42	0.00	0.00	0.000	24.0	0.0	*
17.06.2023	20.28	20.18	0.10	0.00	0.42	0.00	-200.00	0.00	0.42	-200.00	-0.42	0.00	0.00	0.000	24.0	0.0	*
18.06.2023	19.95	19.88	0.07	0.00	0.42	0.00	-200.00	0.00	0.42	-200.00	-0.42	0.00	0.00	0.000	24.0	0.0	*
19.06.2023	18.89	19.31	-0.42	1.55	0.42	0.00	114.72	1.55	0.42	114.72	1.13	0.00	0.00	0.000	24.0	0.0	*
20.06.2023	18.75	18.98	-0.23	4.16	0.42	0.00	163.32	4.16	0.42	163.32	3.74	0.00	0.00	0.000	24.0	0.0	*
21.06.2023	18.57	18.85	-0.28	4.51	0.42	0.00	165.92	4.51	0.42	165.92	4.09	0.00	0.00	0.000	24.0	0.0	*
22.06.2023	18.41	18.57	-0.16	2.43	0.41	0.00	142.25	2.43	0.41	142.25	2.02	0.00	0.00	0.000	24.0	0.0	*
23.06.2023	18.36	18.10	0.26	0.00	0.40	0.00	-200.00	0.00	0.40	-200.00	-0.40	0.00	0.00	0.000	24.0	0.0	*
24.06.2023	18.78	18.83	-0.05	0.00	0.42	0.00	-200.00	0.00	0.42	-200.00	-0.42	0.00	0.00	0.000	24.0	0.0	*
25.06.2023	19.37	19.39	-0.02	0.00	0.42	0.00	-200.00	0.00	0.42	-200.00	-0.42	0.00	0.00	0.000	24.0	0.0	*
26.06.2023	19.62	19.62	0.00	0.00	0.43	0.00	-200.00	0.00	0.43	-200.00	-0.43	0.00	0.00	0.000	24.0	0.0	*
27.06.2023	19.74	19.70	0.04	0.00	0.42	0.00	-200.00	0.00	0.42	-200.00	-0.42	0.00	0.00	0.000	24.0	0.0	*
28.06.2023	20.02	19.91	0.11	0.00	0.38	0.00	-200.00	0.00	0.38	-200.00	-0.38	0.00	0.00	0.000	22.0	2.0	*
29.06.2023	20.45	20.26	0.19	0.00	0.41	0.00	-200.00	0.00	0.41	-200.00	-0.41	0.00	0.00	0.000	24.0	0.0	*
30.06.2023	20.84	20.56	0.28	0.00	0.42	0.00	-200.00	0.00	0.42	-200.00	-0.42	0.00	0.00	0.000	24.0	0.0	*
Средние:	20.34	20.15	0.19	---	---	---	-153.79	---	---	-153.79	---	0.00	0.00	---	---	---	
Итого:	---	---	---	12.65	12.54	0.00	---	12.65	12.54	---	0.11	---	---	0.000	718.0	2.0	

Дата	V1	V2	V3	M1	M2	Mг	Qo	ВНР	ВОС
	м3	м3	м3	т	т	т	Гкал	ч	ч
31.05.2023	4740.38	4702.20	0.00	4575.95	4612.06	-36.11	150.543	3988.0	535.0
30.06.2023	4753.03	4714.74	0.00	4588.60	4624.60	-36.00	150.543	4706.0	537.0
Итого:	12.65	12.54	0.00	12.65	12.54	0.11	0.000	718.0	2.0

Представитель абонента

Представитель энергоснабжающей организации