

Отчет о суточных параметрах
(01.10.2023 0:00:00 - 31.10.2023 0:00:00)

Объект: Пермь г, Кавалерийская ул, д. 30 (2.2 МКД УК "Профком")

Прибор: ВКТ-7 Заводской номер: 00130365

Точка измерения: ТВ1; Ресурс: ТС

Схема измерений: Закрытая система отопления (Схема 3)

Дата	t1	t2	dt	V1	V2	%	M1	M2	%	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3		т	т		т	кг/см2	кг/см2	Гкал	ч	ч	
01.10.2023	36.80	34.31	2.49	69.74	70.07	-0.47	69.28	69.67	-0.56	-0.39	0.00	0.00	0.173	24.0	0.0	
02.10.2023	36.74	33.90	2.84	59.62	59.87	-0.43	59.23	59.54	-0.53	-0.32	0.00	0.00	0.168	24.0	0.0	
03.10.2023	36.70	33.57	3.13	53.52	53.73	---	53.17	53.43	-0.49	-0.26	0.00	0.00	0.167	24.0	0.0	
04.10.2023	36.68	33.45	3.23	52.95	53.15	-0.38	52.60	52.86	-0.49	-0.26	0.00	0.00	0.170	24.0	0.0	
05.10.2023	36.72	33.38	3.34	51.62	51.81	-0.37	51.28	51.54	-0.50	-0.26	0.00	0.00	0.171	24.0	0.0	
06.10.2023	36.77	33.31	3.46	50.90	51.08	-0.36	50.56	50.81	---	-0.25	0.00	0.00	0.174	24.0	0.0	
07.10.2023	38.21	34.41	3.80	50.62	50.80	-0.35	50.26	50.51	-0.49	-0.25	0.00	0.00	0.191	24.0	0.0	
08.10.2023	40.25	35.84	4.41	50.66	50.83	-0.34	50.25	50.51	-0.50	-0.25	0.00	0.00	0.221	24.0	0.0	
09.10.2023	43.28	38.15	5.13	50.71	50.87	-0.31	50.25	50.51	-0.51	-0.26	0.00	0.00	0.257	24.0	0.0	
10.10.2023	45.29	39.52	5.77	50.78	50.91	-0.26	50.27	50.52	-0.49	-0.25	0.00	0.00	0.289	24.0	0.0	
11.10.2023	45.64	39.76	5.88	50.76	50.89	-0.26	50.25	50.50	-0.50	-0.25	0.00	0.00	0.294	24.0	0.0	
12.10.2023	46.13	40.05	6.08	50.76	50.89	-0.24	50.24	50.49	-0.49	-0.25	0.00	0.00	0.305	24.0	0.0	
13.10.2023	43.19	37.74	5.45	42.21	42.35	-0.32	41.83	42.05	-0.53	-0.22	0.00	0.00	0.227	24.0	0.0	*
14.10.2023	43.83	38.36	5.47	50.38	50.51	-0.25	49.91	50.15	-0.47	-0.24	0.00	0.00	0.273	24.0	0.0	
15.10.2023	43.86	38.49	5.37	50.36	50.49	-0.26	49.89	50.12	-0.47	-0.24	0.00	0.00	0.267	24.0	0.0	
16.10.2023	37.11	33.55	3.56	49.92	50.08	-0.33	49.58	49.81	-0.46	-0.23	0.00	0.00	0.176	24.0	0.0	
17.10.2023	37.12	33.48	3.64	49.67	49.82	-0.32	49.33	49.55	-0.44	-0.22	0.00	0.00	0.179	24.0	0.0	
18.10.2023	43.78	38.10	5.68	49.17	49.28	-0.23	48.71	48.93	-0.45	-0.22	0.00	0.00	0.276	24.0	0.0	
19.10.2023	45.44	39.35	6.09	48.42	48.52	-0.20	47.94	48.15	-0.45	-0.21	0.00	0.00	0.291	24.0	0.0	
20.10.2023	45.52	39.41	6.11	48.39	48.49	-0.21	47.90	48.12	-0.46	-0.22	0.00	0.00	0.292	24.0	0.0	
21.10.2023	48.40	41.40	7.00	48.41	48.48	-0.14	47.87	48.08	-0.45	-0.22	0.00	0.00	0.335	24.0	0.0	
22.10.2023	48.78	41.65	7.13	48.38	48.45	-0.14	47.83	48.04	-0.44	-0.21	0.00	0.00	0.340	24.0	0.0	
23.10.2023	49.24	41.89	7.35	48.35	48.41	-0.12	47.79	48.00	-0.43	-0.21	0.00	0.00	0.351	24.0	0.0	
24.10.2023	49.59	42.18	7.41	48.91	48.97	-0.12	48.34	48.55	-0.44	-0.21	0.00	0.00	0.357	24.0	0.0	
25.10.2023	52.01	44.00	8.01	49.57	49.61	-0.09	48.93	49.15	-0.44	-0.22	0.00	0.00	0.391	24.0	0.0	
26.10.2023	52.27	44.13	8.14	49.43	49.47	-0.08	48.79	49.00	-0.43	-0.21	0.00	0.00	0.396	24.0	0.0	
27.10.2023	52.35	44.15	8.20	49.34	49.37	-0.07	48.69	48.91	-0.43	-0.21	0.00	0.00	0.398	24.0	0.0	
28.10.2023	52.51	44.05	8.46	49.12	49.15	-0.05	48.48	48.69	-0.43	-0.21	0.00	0.00	0.410	24.0	0.0	
29.10.2023	52.03	43.88	8.15	49.35	49.39	-0.07	48.71	48.93	-0.44	-0.21	0.00	0.00	0.396	24.0	0.0	
30.10.2023	50.60	42.83	7.77	40.90	40.94	-0.10	40.40	40.57	-0.43	-0.18	0.00	0.00	0.313	20.0	4.0	*
31.10.2023	49.34	41.76	7.58	48.94	49.00	-0.11	48.37	48.58	-0.44	-0.21	0.00	0.00	0.366	24.0	0.0	
Средние:	44.39	38.71	5.68	---	---	-0.24	---	---	-0.47	---	0.00	0.00	---	---	---	
Итого:	---	---	---	1561.85	1565.66	---	1546.94	1554.25	---	-7.32	---	---	8.614	740.0	4.0	

Дата	V1	V2	M1	M2	Mг	Qo	ВНР	ВОС
	м3	м3	т	т	т	Гкал	ч	ч
30.09.2023	9808.62	9819.71	9683.18	9729.94	-46.76	78.281	8143.0	5.0
31.10.2023	11370.47	11385.38	11230.12	11284.19	-54.07	86.895	8883.0	9.0
Итого:	1561.85	1565.66	1546.94	1554.25	-7.32	8.614	740.0	4.0

Представитель абонента

Представитель энергоснабжающей организации