

Отчет о суточных параметрах  
(01.12.2023 0:00:00 - 31.12.2023 0:00:00)

Объект: Пермь г, Солдатова ул, д. 43 (1.1 МКД УК Профком)  
Прибор: ТВ7 Заводской номер: 12000295  
Точка измерения: ТВ1; Ресурс: ТС

Схема измерений: Закрытая система отопления (измерение расхода в двух трубопроводах) (Схема 6)

Дата	t1	t2	dt	V1	V2	M1	M2	%	P1	P2	Qтв	ВНР	ВОС	НС
	°C	°C	°C	м3	м3	т	т	т	кгс/см2	кгс/см2	ГКал	ч	ч	
01.12.2023	56.49	46.60	9.89	434.07	437.08	427.67	432.69	-1.17	6.12	5.12	4.238	24.0	0.0	
02.12.2023	58.01	47.76	10.25	434.20	437.46	427.49	432.85	-1.25	6.12	5.12	4.388	24.0	0.0	
03.12.2023	60.53	49.48	11.05	434.24	438.05	426.95	433.07	-1.42	6.12	5.12	4.727	24.0	0.0	
04.12.2023	60.70	49.54	11.15	434.77	438.95	427.40	433.95	-1.52	6.12	5.12	4.775	24.0	0.0	
05.12.2023	63.23	51.07	12.16	434.70	439.10	426.75	433.77	-1.63	6.12	5.12	5.196	24.0	0.0	
06.12.2023	74.37	58.34	16.03	434.99	441.27	424.32	434.33	-2.33	6.12	5.12	6.815	24.0	0.0	
07.12.2023	78.29	60.93	17.36	435.61	443.28	423.91	435.72	-2.75	6.12	5.12	7.376	24.0	0.0	
08.12.2023	77.35	59.99	17.36	436.43	443.80	424.94	436.46	-2.68	6.12	5.12	7.392	24.0	0.0	
09.12.2023	76.13	58.98	17.14	436.69	443.62	425.51	436.49	-2.55	6.12	5.12	7.308	24.0	0.0	
10.12.2023	75.63	58.56	17.07	437.00	444.74	425.94	437.72	-2.73	6.12	5.12	7.284	24.0	0.0	
11.12.2023	75.61	58.45	17.17	437.33	444.64	426.31	437.64	-2.62	6.12	5.12	7.332	24.0	0.0	
12.12.2023	75.45	58.01	17.44	437.01	444.11	426.01	437.21	-2.60	6.12	5.12	7.443	24.0	0.0	
13.12.2023	75.03	57.77	17.26	437.03	444.45	426.13	437.59	-2.65	6.12	5.12	7.370	24.0	0.0	
14.12.2023	70.37	54.90	15.47	437.17	443.13	427.44	436.94	-2.20	6.12	5.12	6.622	24.0	0.0	
15.12.2023	67.33	53.22	14.11	437.01	443.29	428.03	437.47	-2.18	6.12	5.12	6.050	24.0	0.0	
16.12.2023	64.39	51.32	13.07	437.01	442.49	428.77	437.07	-1.92	6.12	5.12	5.614	24.0	0.0	
17.12.2023	64.47	51.51	12.96	437.06	442.42	428.80	436.99	-1.89	6.12	5.12	5.565	24.0	0.0	
18.12.2023	61.52	49.60	11.93	436.86	442.15	429.26	437.11	-1.81	6.12	5.12	5.129	24.0	0.0	
19.12.2023	56.26	46.14	10.12	428.90	432.95	422.64	428.69	-1.42	6.12	5.12	4.284	24.0	0.0	
20.12.2023	51.57	43.04	8.53	441.33	443.79	435.91	440.03	-0.94	6.12	5.12	3.725	24.0	0.0	
21.12.2023	48.43	40.88	7.55	441.05	443.19	436.28	439.84	-0.81	6.12	5.12	3.299	24.0	0.0	
22.12.2023	47.88	40.53	7.35	440.43	442.77	435.78	439.46	-0.84	6.12	5.12	3.209	24.0	0.0	
23.12.2023	51.24	42.97	8.27	440.40	443.51	435.05	439.75	-1.07	6.12	5.12	3.606	24.0	0.0	
24.12.2023	53.54	44.69	8.85	442.81	447.21	436.93	443.10	-1.40	6.12	5.12	3.875	24.0	0.0	
25.12.2023	53.43	44.66	8.77	443.55	448.68	437.71	444.56	-1.55	6.12	5.12	3.845	24.0	0.0	
26.12.2023	54.26	45.26	9.00	443.11	448.26	437.08	444.03	-1.58	6.12	5.12	3.941	24.0	0.0	
27.12.2023	58.02	47.81	10.20	441.76	446.61	434.93	441.88	-1.59	6.12	5.12	4.446	24.0	0.0	
28.12.2023	60.82	49.01	11.81	378.83	383.67	372.39	379.37	-1.86	6.12	5.12	4.406	24.0	0.0	
29.12.2023	64.00	51.90	12.10	445.23	451.55	436.90	445.93	-2.05	6.12	5.12	5.296	24.0	0.0	
30.12.2023	68.11	54.46	13.65	444.64	451.85	435.34	445.65	-2.34	6.12	5.12	5.954	24.0	0.0	
31.12.2023	72.04	57.23	14.81	445.33	452.64	435.01	445.79	-2.45	6.12	5.12	6.454	24.0	0.0	
Средние:	63.69	51.12	12.58	---	---	---	---	-1.86	6.12	5.12	---	---	---	
Итого:	---	---	---	13526.54	13690.71	13273.56	13523.15	---	---	---	166.965	744.0	0.0	

Дата	V1	V2	M1	M2	dM	Qтв	Q12	Qг	ВНР	ВОС
	м3	м3	т	т	т	ГКал	ГКал	ГКал	ч	ч
30.11.2023	819517.67	824797.38	807488.08	816251.41	0.00	7185.550	0.000	0.000	1753.0	2469.0
31.12.2023	833044.21	838488.09	820761.64	829774.57	0.00	7352.515	0.000	0.000	2497.0	2469.0
Итого:	13526.54	13690.71	13273.56	13523.15	0.00	166.965	0.000	0.000	744.0	0.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах ГВС  
(01.12.2023 0:00:00 - 31.12.2023 0:00:00)

Объект: Пермь г, Солдатова ул, д. 43 (1.1 МКД УК Профком)  
Прибор: ТВ7 Заводской номер: 12000295  
Точка измерения: ТВ2; Ресурс: ГВС

Схема измерений: Открытая система отопления (измерение расхода в трёх трубопроводах) (Схема 1)

Дата	t1	t2	dt	V1	V2	V3	M1	M2	M3	%	dM	P1	P2	P3	Qтв	ВНР	ВОС	tx	НС
	°C	°C	°C	м3	м3	м3	т	т	т	т	т	кгс/см2	кгс/см2	кгс/см2	ГКал	ч	ч	°C	
01.12.2023	57.64	44.66	12.98	26.21	5.45	0.00	25.81	5.40	0.00	130.83	20.41	6.12	5.12	3.00	1.145	24.0	0.0	5.00	
02.12.2023	57.83	44.29	13.54	25.61	5.54	0.00	25.22	5.49	0.00	128.53	19.73	6.12	5.12	3.00	1.117	24.0	0.0	5.00	
03.12.2023	58.22	44.54	13.68	27.97	5.41	0.00	27.53	5.36	0.00	134.77	22.17	6.12	5.12	3.00	1.254	24.0	0.0	5.00	
04.12.2023	57.47	43.61	13.86	24.63	5.31	0.00	24.25	5.26	0.00	128.70	18.99	6.12	5.12	3.00	1.070	24.0	0.0	5.00	
05.12.2023	56.61	43.78	12.83	25.57	5.41	0.00	25.19	5.36	0.00	129.79	19.82	6.12	5.12	3.00	1.092	24.0	0.0	5.00	
06.12.2023	57.51	44.11	13.39	24.52	5.52	0.00	24.15	5.47	0.00	126.10	18.67	6.12	5.12	3.00	1.054	24.0	0.0	5.00	
07.12.2023	57.56	43.85	13.70	25.80	5.55	0.00	25.41	5.50	0.00	128.79	19.90	6.12	5.12	3.00	1.122	24.0	0.0	5.00	
08.12.2023	57.30	43.43	13.86	24.43	5.51	0.00	24.06	5.46	0.00	126.00	18.60	6.12	5.12	3.00	1.049	24.0	0.0	5.00	
09.12.2023	57.76	43.68	14.07	26.39	5.59	0.00	25.98	5.55	0.00	129.64	20.44	6.12	5.12	3.00	1.157	24.0	0.0	5.00	
10.12.2023	58.44	43.59	14.86	29.54	5.54	0.00	29.08	5.49	0.00	136.43	23.58	6.12	5.12	3.00	1.343	24.0	0.0	5.00	
11.12.2023	57.60	42.76	14.84	26.34	5.34	0.00	25.94	5.30	0.00	132.17	20.64	6.12	5.12	3.00	1.165	24.0	0.0	5.00	
12.12.2023	57.71	42.07	15.64	27.41	5.39	0.00	26.99	5.34	0.00	133.91	21.65	6.12	5.12	3.00	1.225	24.0	0.0	5.00	
13.12.2023	57.64	42.21	15.43	27.40	5.53	0.00	26.98	5.48	0.00	132.44	21.50	6.12	5.12	3.00	1.217	24.0	0.0	5.00	
14.12.2023	57.33	42.22	15.11	26.47	5.34	0.00	26.06	5.30	0.00	132.44	20.77	6.12	5.12	3.00	1.167	24.0	0.0	5.00	
15.12.2023	57.13	42.80	14.33	24.36	5.38	0.00	24.00	5.33	0.00	127.27	18.66	6.12	5.12	3.00	1.050	24.0	0.0	5.00	
16.12.2023	57.95	43.41	14.54	25.79	5.43	0.00	25.39	5.38	0.00	130.03	20.01	6.12	5.12	3.00	1.138	24.0	0.0	5.00	
17.12.2023	58.27	43.72	14.55	29.00	5.57	0.00	28.55	5.52	0.00	135.16	23.03	6.12	5.12	3.00	1.308	24.0	0.0	5.00	
18.12.2023	57.32	40.98	16.34	24.60	5.46	0.00	24.23	5.42	0.00	126.89	18.81	6.12	5.12	3.00	1.073	24.0	0.0	5.00	
19.12.2023	57.49	40.69	16.80	25.08	5.36	0.00	24.70	5.32	0.00	129.12	19.38	6.12	5.12	3.00	1.107	24.0	0.0	5.00	
20.12.2023	57.59	40.83	16.76	26.07	5.45	0.00	25.67	5.41	0.00	130.37	20.26	6.12	5.12	3.00	1.157	24.0	0.0	5.00	
21.12.2023	57.71	41.29	16.42	26.70	5.46	0.00	26.29	5.42	0.00	131.63	20.87	6.12	5.12	3.00	1.190	24.0	0.0	5.00	
22.12.2023	57.06	41.00	16.07	24.57	5.41	0.00	24.20	5.37	0.00	127.33	18.83	6.12	5.12	3.00	1.067	24.0	0.0	5.00	
23.12.2023	57.95	41.60	16.36	27.22	5.43	0.00	26.80	5.39	0.00	133.00	21.41	6.12	5.12	3.00	1.222	24.0	0.0	5.00	
24.12.2023	58.50	42.36	16.14	30.52	5.67	0.00	30.04	5.62	0.00	136.95	24.42	6.12	5.12	3.00	1.398	24.0	0.0	5.00	
25.12.2023	57.64	41.42	16.22	26.17	5.35	0.00	25.77	5.31	0.00	131.70	20.46	6.12	5.12	3.00	1.164	24.0	0.0	5.00	
26.12.2023	57.32	41.13	16.19	24.77	5.27	0.00	24.40	5.23	0.00	129.40	19.17	6.12	5.12	3.00	1.088	24.0	0.0	5.00	
27.12.2023	57.62	41.62	16.00	26.44	5.34	0.00	26.03	5.29	0.00	132.41	20.74	6.12	5.12	3.00	1.176	24.0	0.0	5.00	
28.12.2023	56.41	41.00	15.42	25.05	4.62	0.00	24.68	4.58	0.00	137.40	20.10	6.12	5.12	3.00	1.105	24.0	0.0	5.00	
29.12.2023	57.22	41.46	15.76	25.26	5.42	0.00	24.88	5.38	0.00	128.89	19.50	6.12	5.12	3.00	1.103	24.0	0.0	5.00	
30.12.2023	58.35	41.79	16.56	28.98	5.46	0.00	28.53	5.42	0.00	136.17	23.11	6.12	5.12	3.00	1.323	24.0	0.0	5.00	
31.12.2023	58.96	42.46	16.51	36.58	5.46	0.00	36.00	5.41	0.00	147.73	30.59	6.12	5.12	3.00	1.741	24.0	0.0	5.00	
Средние:	57.65	42.53	15.12	---	---	---	---	---	---	131.68	---	6.12	5.12	3.00	---	---	---	5.00	
Итого:	---	---	---	825.47	167.97	0.00	812.80	166.57	0.00	---	646.23	---	---	---	36.588	744.0	0.0	---	

Дата	V1	V2	V3	M1	M2	M3	dM	Qтв	Q12	Qг	ВНР	ВОС
	м3	м3	м3	т	т	т	т	ГКал	ГКал	ГКал	ч	ч
30.11.2023	91648.72	40154.45	0.00	90287.50	39729.27	0.00	46187.35	2872.347	0.000	0.000	1762.0	2460.0
31.12.2023	92474.19	40322.42	0.00	91100.30	39895.84	0.00	46833.57	2908.935	0.000	0.000	2506.0	2460.0
Итого:	825.47	167.97	0.00	812.80	166.57	0.00	646.23	36.588	0.000	0.000	744.0	0.0

Представитель абонента

Представитель энергоснабжающей организации