

Отчет о суточных параметрах
(01.01.2024 0:00:00 - 31.01.2024 0:00:00)

Объект: Пермь г, Анвара Гатауллина ул, д. 13 (1.2 МКД (УК ПрофКом) 2эт.)

Прибор: ВКТ-7 Заводской номер: 111782

Точка измерения: ТВ1; Ресурс: ТС

Схема измерений: Закрытая система отопления, дополнительный канал измерения расхода по тр3 (Схема 3)

Дата	t1	t2	dt	V1	V2	V3	%	M1	M2	%	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3	м3		Т	Т		Т	кг/см2	кг/см2	Гкал	ч	ч	
01.01.2024	99.73	56.10	43.63	27.00	26.57	0.00	1.61	25.86	26.14	-1.08	-0.28	0.00	0.00	1.130	24.0	0.0	*
02.01.2024	100.74	53.34	47.40	24.44	24.05	0.00	1.61	23.48	23.81	-1.40	-0.33	0.00	0.00	1.115	24.0	0.0	*
03.01.2024	98.69	50.98	47.71	23.05	22.72	0.00	1.44	22.15	22.48	-1.48	-0.33	0.00	0.00	1.056	24.0	0.0	*
04.01.2024	92.52	48.59	43.93	22.97	22.75	0.00	0.96	22.10	22.51	-1.84	-0.41	0.00	0.00	0.972	24.0	0.0	*
05.01.2024	97.47	52.48	44.99	24.75	24.40	0.00	1.42	23.79	24.16	-1.54	-0.37	0.00	0.00	1.070	24.0	0.0	*
06.01.2024	96.89	52.75	44.14	25.31	24.96	0.00	1.39	24.26	24.63	-1.51	-0.37	0.00	0.00	1.071	24.0	0.0	*
07.01.2024	101.28	55.36	45.92	26.85	26.37	0.00	1.80	25.70	25.94	-0.93	-0.24	0.00	0.00	1.180	24.0	0.0	*
08.01.2024	102.37	56.07	46.30	27.32	26.74	0.00	2.15	26.12	26.26	-0.53	-0.14	0.00	0.00	1.214	24.0	0.0	*
09.01.2024	102.92	56.88	46.04	27.70	27.05	0.00	2.37	26.49	26.57	-0.30	-0.08	0.00	0.00	1.224	24.0	0.0	*
10.01.2024	103.12	56.10	47.02	26.46	25.81	0.00	2.49	25.28	25.44	-0.63	-0.16	0.00	0.00	1.189	24.0	0.0	*
11.01.2024	102.83	55.13	47.70	25.64	25.00	0.00	2.53	24.44	24.71	-1.10	-0.27	0.00	0.00	1.170	24.0	0.0	*
12.01.2024	103.22	56.08	47.14	26.36	25.64	0.00	2.77	25.16	25.23	-0.28	-0.07	0.00	0.00	1.188	24.0	0.0	*
13.01.2024	96.84	52.37	44.47	25.26	24.65	0.00	2.44	24.23	24.33	-0.41	-0.10	0.00	0.00	1.078	24.0	0.0	*
14.01.2024	99.52	54.48	45.04	27.20	26.50	0.00	2.61	26.06	26.10	-0.15	-0.04	0.00	0.00	1.177	24.0	0.0	*
15.01.2024	98.60	55.03	43.57	27.10	26.39	0.00	2.65	26.01	26.01	0.00	0.00	0.00	0.00	1.134	24.0	0.0	*
16.01.2024	87.38	47.57	39.81	20.19	19.72	0.00	2.36	19.50	19.54	-0.20	-0.04	0.00	0.00	0.780	24.0	0.0	*
17.01.2024	84.07	48.63	35.44	26.01	25.63	0.00	1.47	25.22	25.39	-0.67	-0.17	0.00	0.00	0.891	24.0	0.0	*
18.01.2024	84.58	48.51	36.07	25.72	25.27	0.00	1.77	24.92	25.03	-0.44	-0.11	0.00	0.00	0.898	24.0	0.0	*
19.01.2024	85.85	49.07	36.78	26.13	25.63	0.00	1.93	25.33	25.39	-0.24	-0.06	0.00	0.00	0.932	24.0	0.0	*
20.01.2024	79.89	48.52	31.37	27.38	26.93	0.00	1.66	26.58	26.69	-0.41	-0.11	0.00	0.00	0.833	24.0	0.0	*
21.01.2024	76.68	46.44	30.24	26.23	25.87	0.00	1.38	25.51	25.63	-0.47	-0.12	0.00	0.00	0.771	24.0	0.0	*
22.01.2024	86.95	50.15	36.80	26.21	25.71	0.00	1.93	25.31	25.47	-0.63	-0.16	0.00	0.00	0.933	24.0	0.0	*
23.01.2024	89.98	50.65	39.33	25.23	24.70	0.00	2.12	24.29	24.46	-0.70	-0.17	0.00	0.00	0.956	24.0	0.0	*
24.01.2024	89.16	50.44	38.72	24.89	24.38	0.00	2.07	24.04	24.14	-0.42	-0.10	0.00	0.00	0.930	24.0	0.0	*
25.01.2024	88.52	49.42	39.10	23.74	23.27	0.00	2.00	23.02	23.03	-0.04	-0.01	0.00	0.00	0.900	24.0	0.0	*
26.01.2024	87.70	51.51	36.19	21.94	21.39	0.00	2.54	21.25	21.13	0.57	0.12	0.00	0.00	0.769	24.0	0.0	*
27.01.2024	87.39	48.69	38.70	23.21	22.81	0.00	1.74	22.49	22.57	-0.36	-0.08	0.00	0.00	0.872	24.0	0.0	*
28.01.2024	86.44	48.51	37.93	23.04	22.64	0.00	1.75	22.30	22.40	-0.45	-0.10	0.00	0.00	0.846	24.0	0.0	*
29.01.2024	83.17	47.04	36.13	22.75	22.41	0.00	1.51	22.03	22.17	-0.63	-0.14	0.00	0.00	0.796	24.0	0.0	*
30.01.2024	79.65	46.38	33.27	23.39	23.08	0.00	1.33	22.67	22.84	-0.75	-0.17	0.00	0.00	0.756	24.0	0.0	*
31.01.2024	72.97	44.04	28.93	23.03	22.83	0.00	0.87	22.46	22.59	-0.58	-0.13	0.00	0.00	0.650	24.0	0.0	*
Средние:	91.84	51.20	40.64	---	---	---	1.89	---	---	-0.63	---	0.00	0.00	---	---	---	---
Итого:	---	---	---	776.50	761.87	0.00	---	748.05	752.79	---	-4.74	---	---	30.481	744.0	0.0	---

Дата	V1	V2	V3	M1	M2	Mг	Qo	ВНР	ВОС
	м3	м3	м3	Т	Т	Т	Гкал	ч	ч
31.12.2023	6900.88	6858.18	0.00	5970.92	6031.48	-60.56	187.600	8440.0	1219.0
31.01.2024	7677.38	7620.05	0.00	6718.97	6784.27	-65.30	218.081	9184.0	1219.0
Итого:	776.50	761.87	0.00	748.05	752.79	-4.74	30.481	744.0	0.0

Представитель абонента

Представитель энергоснабжающей организации