

Отчет о суточных параметрах
(01.01.2024 0:00:00 - 31.01.2024 0:00:00)

Объект: Пермь г, Солдатова ул, д. 43 (1.1 МКД ООО "ПРОФКОМ")

Прибор: ТВ7 Заводской номер: 12000295

Точка измерения: ТВ1; Ресурс: ТС

Схема измерений: Закрытая система отопления (измерение расхода в двух трубопроводах) (Схема 6)

Дата	t1	t2	dt	V1	V2	M1	M2	%	P1	P2	Qтв	ВНР	ВОС	НС
	°C	°C	°C	м3	м3	т	т	т	кгс/см2	кгс/см2	ГКал	ч	ч	
01.01.2024	71.25	56.85	14.40	445.68	452.81	435.57	446.04	-2.38	6.12	5.12	6.284	24.0	0.0	
02.01.2024	74.91	58.94	15.97	445.13	453.54	434.09	446.26	-2.77	6.12	5.12	6.948	24.0	0.0	
03.01.2024	75.81	59.47	16.33	445.00	453.12	433.70	445.74	-2.74	6.12	5.12	7.098	24.0	0.0	
04.01.2024	72.62	57.40	15.23	444.76	452.08	434.29	445.19	-2.48	6.12	5.12	6.625	24.0	0.0	
05.01.2024	73.82	58.17	15.65	444.07	451.73	433.34	444.67	-2.58	6.12	5.12	6.797	24.0	0.0	
06.01.2024	75.54	59.19	16.35	444.04	452.02	432.84	444.70	-2.70	6.12	5.12	7.090	24.0	0.0	
07.01.2024	76.56	59.97	16.59	443.86	451.96	432.40	444.47	-2.75	6.12	5.12	7.186	24.0	0.0	
08.01.2024	76.44	59.73	16.72	443.83	451.65	432.40	444.24	-2.70	6.12	5.12	7.244	24.0	0.0	
09.01.2024	74.32	58.40	15.93	443.70	451.06	432.82	443.94	-2.54	6.12	5.12	6.906	24.0	0.0	
10.01.2024	73.41	57.57	15.84	443.28	450.70	432.65	443.79	-2.54	6.12	5.12	6.868	24.0	0.0	
11.01.2024	75.54	59.02	16.51	443.22	451.44	432.04	444.16	-2.77	6.12	5.12	7.149	24.0	0.0	
12.01.2024	75.43	59.07	16.36	442.94	450.91	431.78	443.66	-2.71	6.12	5.12	7.076	24.0	0.0	
13.01.2024	75.48	58.99	16.49	443.05	451.02	431.89	443.80	-2.72	6.12	5.12	7.135	24.0	0.0	
14.01.2024	74.34	58.28	16.06	443.44	451.06	432.55	443.97	-2.61	6.12	5.12	6.962	24.0	0.0	
15.01.2024	69.63	55.05	14.58	443.17	450.68	433.51	444.34	-2.47	6.12	5.12	6.334	24.0	0.0	
16.01.2024	64.28	51.41	12.87	443.13	449.63	434.79	444.09	-2.12	6.12	5.12	5.604	24.0	0.0	
17.01.2024	60.20	48.58	11.62	442.66	448.59	435.28	443.68	-1.91	6.12	5.12	5.066	24.0	0.0	
18.01.2024	61.03	49.20	11.82	442.47	448.94	434.93	443.89	-2.04	6.12	5.12	5.150	24.0	0.0	
19.01.2024	62.33	50.12	12.21	442.35	449.54	434.50	444.31	-2.23	6.12	5.12	5.314	24.0	0.0	
20.01.2024	56.58	46.37	10.21	442.03	448.63	435.49	444.16	-1.97	6.12	5.12	4.455	24.0	0.0	
21.01.2024	56.08	46.00	10.08	441.75	446.95	435.31	442.57	-1.65	6.12	5.12	4.397	24.0	0.0	
22.01.2024	63.41	51.05	12.37	442.08	448.37	433.96	442.95	-2.05	6.12	5.12	5.376	24.0	0.0	
23.01.2024	65.00	52.28	12.72	442.30	449.28	433.82	443.58	-2.22	6.12	5.12	5.529	24.0	0.0	
24.01.2024	63.87	51.66	12.20	442.20	449.03	433.98	443.47	-2.16	6.12	5.12	5.305	24.0	0.0	
25.01.2024	63.02	51.18	11.84	445.11	450.74	437.03	445.27	-1.87	6.12	5.12	5.182	24.0	0.0	
26.01.2024	63.06	51.29	11.78	447.48	453.52	439.34	447.98	-1.95	6.12	5.12	5.183	24.0	0.0	
27.01.2024	63.13	51.34	11.80	447.26	453.11	439.14	447.58	-1.90	6.12	5.12	5.190	24.0	0.0	
28.01.2024	62.06	50.65	11.41	447.18	452.81	439.31	447.39	-1.82	6.12	5.12	5.022	24.0	0.0	
29.01.2024	60.65	49.70	10.96	446.66	452.11	439.11	446.90	-1.76	6.12	5.12	4.819	24.0	0.0	
30.01.2024	59.35	48.85	10.49	446.31	451.60	439.08	446.59	-1.69	6.12	5.12	4.616	24.0	0.0	
31.01.2024	54.26	45.37	8.90	445.84	450.04	439.78	445.76	-1.35	6.12	5.12	3.919	24.0	0.0	
Средние:	67.53	53.91	13.62	---	---	---	---	-2.26	6.12	5.12	---	---	---	
Итого:	---	---	---	13765.96	13978.64	13480.72	13789.16	---	---	---	183.826	744.0	0.0	

Дата	V1	V2	M1	M2	dM	Qтв	Q12	Qг	ВНР	ВОС
	м3	м3	т	т	т	ГКал	ГКал	ГКал	ч	ч
31.12.2023	833044.21	838488.09	820761.64	829774.57	0.00	7352.515	0.000	0.000	2497.0	2469.0
31.01.2024	846810.17	852466.74	834242.36	843563.73	0.00	7536.341	0.000	0.000	3241.0	2469.0
Итого:	13765.96	13978.64	13480.72	13789.16	0.00	183.826	0.000	0.000	744.0	0.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах ГВС
(01.01.2024 0:00:00 - 31.01.2024 0:00:00)

Объект: Пермь г, Солдатова ул, д. 43 (1.1 МКД ООО "ПРОФКОМ")

Прибор: ТВ7 Заводской номер: 12000295

Точка измерения: ТВ2; Ресурс: ГВС

Схема измерений: Открытая система отопления (измерение расхода в трёх трубопроводах) (Схема 1)

Дата	t1 °C	t2 °C	dt °C	V1 м3	V2 м3	V3 м3	M1 т	M2 т	M3 т	% т	dM т	P1 кгс/см2	P2 кгс/см2	P3 кгс/см2	Qтв ГКал	ВНР ч	ВОС ч	tx °C	НС
01.01.2024	55.92	40.17	15.75	19.84	5.13	0.00	19.55	5.09	0.00	117.38	14.46	6.12	5.12	3.00	0.817	24.0	0.0	5.00	
02.01.2024	57.01	40.50	16.51	23.31	5.24	0.00	22.96	5.20	0.00	126.11	17.75	6.12	5.12	3.00	1.010	24.0	0.0	5.00	
03.01.2024	57.09	40.30	16.79	24.81	5.31	0.00	24.43	5.27	0.00	129.04	19.17	6.12	5.12	3.00	1.087	24.0	0.0	5.00	
04.01.2024	57.34	40.58	16.76	26.98	5.27	0.00	26.58	5.23	0.00	134.20	21.34	6.12	5.12	3.00	1.205	24.0	0.0	5.00	
05.01.2024	57.31	40.60	16.70	25.89	5.19	0.00	25.50	5.16	0.00	132.73	20.35	6.12	5.12	3.00	1.151	24.0	0.0	5.00	
06.01.2024	57.15	40.30	16.85	23.54	5.25	0.00	23.18	5.21	0.00	126.60	17.97	6.12	5.12	3.00	1.026	24.0	0.0	5.00	
07.01.2024	57.63	41.01	16.62	24.69	5.14	0.00	24.31	5.11	0.00	130.56	19.20	6.12	5.12	3.00	1.096	24.0	0.0	5.00	
08.01.2024	57.95	39.78	18.17	30.19	5.29	0.00	29.72	5.25	0.00	139.96	24.47	6.12	5.12	3.00	1.392	24.0	0.0	5.00	
09.01.2024	57.96	38.04	19.92	28.68	5.04	0.00	28.23	5.01	0.00	139.73	23.23	6.12	5.12	3.00	1.330	24.0	0.0	5.00	
10.01.2024	57.90	37.79	20.11	28.14	5.07	0.00	27.70	5.04	0.00	138.46	22.67	6.12	5.12	3.00	1.301	24.0	0.0	5.00	
11.01.2024	57.42	37.38	20.04	25.43	5.05	0.00	25.05	5.02	0.00	133.22	20.03	6.12	5.12	3.00	1.151	24.0	0.0	5.00	
12.01.2024	57.36	37.31	20.05	25.05	4.95	0.00	24.67	4.92	0.00	133.54	19.76	6.12	5.12	3.00	1.134	24.0	0.0	5.00	
13.01.2024	57.98	37.87	20.11	27.96	5.11	0.00	27.52	5.07	0.00	137.73	22.45	6.12	5.12	3.00	1.292	24.0	0.0	5.00	
14.01.2024	58.18	38.48	19.70	28.80	5.50	0.00	28.35	5.46	0.00	135.39	22.89	6.12	5.12	3.00	1.325	24.0	0.0	5.00	
15.01.2024	57.57	37.38	20.19	26.42	5.06	0.00	26.01	5.02	0.00	135.25	20.99	6.12	5.12	3.00	1.206	24.0	0.0	5.00	
16.01.2024	57.66	36.97	20.68	26.24	4.96	0.00	25.84	4.93	0.00	135.90	20.91	6.12	5.12	3.00	1.204	24.0	0.0	5.00	
17.01.2024	57.54	36.62	20.92	26.18	4.96	0.00	25.78	4.93	0.00	135.76	20.85	6.12	5.12	3.00	1.199	24.0	0.0	5.00	
18.01.2024	57.66	36.98	20.69	26.67	4.88	0.00	26.26	4.85	0.00	137.69	21.42	6.12	5.12	3.00	1.229	24.0	0.0	5.00	
19.01.2024	57.64	36.95	20.69	25.84	4.89	0.00	25.44	4.86	0.00	135.86	20.58	6.12	5.12	3.00	1.185	24.0	0.0	5.00	
20.01.2024	57.82	37.58	20.25	27.85	4.98	0.00	27.42	4.95	0.00	138.87	22.47	6.12	5.12	3.00	1.288	24.0	0.0	5.00	
21.01.2024	58.11	37.71	20.40	28.54	5.11	0.00	28.09	5.07	0.00	138.80	23.02	6.12	5.12	3.00	1.327	24.0	0.0	5.00	
22.01.2024	57.23	37.42	19.81	26.38	4.93	0.00	25.98	4.90	0.00	136.52	21.08	6.12	5.12	3.00	1.199	24.0	0.0	5.00	
23.01.2024	57.64	37.93	19.71	26.64	4.91	0.00	26.23	4.88	0.00	137.25	21.35	6.12	5.12	3.00	1.221	24.0	0.0	5.00	
24.01.2024	57.30	37.72	19.58	25.71	4.88	0.00	25.32	4.85	0.00	135.72	20.47	6.12	5.12	3.00	1.166	24.0	0.0	5.00	
25.01.2024	57.26	38.05	19.22	25.18	4.95	0.00	24.80	4.92	0.00	133.83	19.88	6.12	5.12	3.00	1.134	24.0	0.0	5.00	
26.01.2024	57.24	38.37	18.87	24.93	4.99	0.00	24.55	4.96	0.00	132.75	19.59	6.12	5.12	3.00	1.117	24.0	0.0	5.00	
27.01.2024	57.27	38.36	18.92	24.61	5.09	0.00	24.24	5.05	0.00	130.98	19.19	6.12	5.12	3.00	1.099	24.0	0.0	5.00	
28.01.2024	58.34	38.95	19.39	31.12	5.10	0.00	30.63	5.07	0.00	143.23	25.56	6.12	5.12	3.00	1.462	24.0	0.0	5.00	
29.01.2024	56.92	38.30	18.62	23.91	5.01	0.00	23.55	4.98	0.00	130.25	18.58	6.12	5.12	3.00	1.058	24.0	0.0	5.00	
30.01.2024	57.41	38.67	18.74	24.95	5.05	0.00	24.57	5.01	0.00	132.24	19.56	6.12	5.12	3.00	1.120	24.0	0.0	5.00	
31.01.2024	57.05	38.67	18.38	24.03	5.05	0.00	23.66	5.02	0.00	130.03	18.65	6.12	5.12	3.00	1.063	24.0	0.0	5.00	
Средние:	57.48	38.48	19.00	---	---	---	---	---	---	134.05	---	6.12	5.12	3.00	---	---	---	5.00	
Итого:	---	---	---	808.50	157.32	0.00	796.15	156.28	0.00	---	639.88	---	---	---	36.591	744.0	0.0	---	

Дата	V1 м3	V2 м3	V3 м3	M1 т	M2 т	M3 т	dM т	Qтв ГКал	Q12 ГКал	Qг ГКал	ВНР ч	ВОС ч
31.12.2023	92474.19	40322.42	0.00	91100.30	39895.84	0.00	46833.57	2908.935	0.000	0.000	2506.0	2460.0
31.01.2024	93282.69	40479.74	0.00	91896.45	40052.12	0.00	47473.45	2945.526	0.000	0.000	3250.0	2460.0
Итого:	808.50	157.32	0.00	796.15	156.28	0.00	639.88	36.591	0.000	0.000	744.0	0.0

Представитель абонента

Представитель энергоснабжающей организации