

Отчет о суточных параметрах
(01.03.2025 0:00:00 - 31.03.2025 0:00:00)

Объект: Пермский край, Пермь г, Героев Хасана ул, д. 159 (ООО "ПРОФКОМ")
Прибор: ВКТ-7 Заводской номер: 00164154
Точка измерения: ТВ1; Ресурс: ТС

Схема измерений: Закрытая система отопления (Схема 3)

Дата	t1	t2	dt	V1	V2	%	M1	M2	%	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3		т	т		т	кг/см2	кг/см2	Гкал	ч	ч	
01.03.2025	58.05	48.32	9.73	1347.24	1328.94	1.37	1326.28	1314.29	0.91	11.99	6.00	4.00	12.940	24.0	0.0	
02.03.2025	56.83	47.40	9.43	1346.68	1328.69	1.34	1326.54	1314.56	0.91	11.98	6.00	4.00	12.546	24.0	0.0	
03.03.2025	58.07	48.33	9.74	1347.39	1328.94	1.38	1326.46	1314.25	0.92	12.21	6.00	4.00	12.952	24.0	0.0	
04.03.2025	59.27	49.11	10.16	1347.84	1329.04	1.40	1326.06	1313.90	0.92	12.16	6.00	4.00	13.511	24.0	0.0	
05.03.2025	59.85	49.48	10.37	1348.04	1329.06	1.42	1325.83	1313.71	0.92	12.12	6.00	4.00	13.775	24.0	0.0	
06.03.2025	59.82	49.65	10.17	1347.87	1329.08	1.40	1325.68	1313.62	0.91	12.06	6.00	4.00	13.522	24.0	0.0	
07.03.2025	59.42	49.36	10.06	1347.71	1329.03	1.40	1325.80	1313.73	0.91	12.07	6.00	4.00	13.358	24.0	0.0	
08.03.2025	60.62	50.07	10.55	1348.27	1329.19	1.43	1325.54	1313.48	0.91	12.06	6.00	4.00	14.019	24.0	0.0	
09.03.2025	60.69	50.18	10.51	1348.31	1329.19	1.43	1325.50	1313.42	0.92	12.08	6.00	4.00	13.976	24.0	0.0	
10.03.2025	58.05	48.51	9.54	1346.80	1328.69	1.35	1325.85	1313.91	0.90	11.94	6.00	4.00	12.689	24.0	0.0	
11.03.2025	55.73	46.84	8.89	1345.89	1328.37	1.31	1326.51	1314.57	0.90	11.94	6.00	4.00	11.830	24.0	0.0	
12.03.2025	51.59	43.95	7.64	1344.12	1327.70	1.23	1327.41	1315.51	0.90	11.90	6.00	4.00	10.183	24.0	0.0	
13.03.2025	50.69	43.32	7.37	1343.81	1327.69	1.21	1327.68	1315.86	0.89	11.82	6.00	4.00	9.814	24.0	0.0	
14.03.2025	48.46	41.72	6.74	1342.80	1327.17	1.17	1327.99	1316.19	0.89	11.80	6.00	4.00	8.980	24.0	0.0	
15.03.2025	47.21	40.90	6.31	1342.23	1326.88	1.15	1328.18	1316.30	0.90	11.88	6.00	4.00	8.415	24.0	0.0	
16.03.2025	50.49	43.02	7.47	1343.65	1327.49	1.21	1327.63	1315.80	0.90	11.83	6.00	4.00	9.945	24.0	0.0	
17.03.2025	52.02	44.28	7.74	1344.16	1327.77	1.23	1327.21	1315.43	0.89	11.78	6.00	4.00	10.302	24.0	0.0	
18.03.2025	53.90	45.44	8.46	1345.09	1328.10	1.27	1326.89	1315.07	0.89	11.82	6.00	4.00	11.247	24.0	0.0	
19.03.2025	58.12	48.45	9.67	1346.93	1328.81	1.35	1325.93	1314.09	0.90	11.84	6.00	4.00	12.848	24.0	0.0	
20.03.2025	54.48	45.95	8.53	1344.95	1327.79	1.28	1326.42	1314.50	0.90	11.92	6.00	4.00	11.353	24.0	0.0	
21.03.2025	54.54	45.85	8.69	1344.98	1327.83	1.28	1326.40	1314.62	0.89	11.78	6.00	4.00	11.551	24.0	0.0	
22.03.2025	53.67	45.31	8.36	1344.99	1328.05	1.27	1326.95	1315.11	0.90	11.84	6.00	4.00	11.131	24.0	0.0	
23.03.2025	51.63	43.84	7.79	1344.28	1327.84	1.23	1327.55	1315.73	0.89	11.82	6.00	4.00	10.374	24.0	0.0	
24.03.2025	49.67	42.58	7.09	1343.20	1327.38	1.18	1327.70	1315.95	0.89	11.75	6.00	4.00	9.439	24.0	0.0	
25.03.2025	49.03	42.15	6.88	1342.59	1328.16	1.08	1327.47	1316.93	0.80	10.54	6.00	4.00	9.159	24.0	0.0	
26.03.2025	47.80	41.28	6.52	1342.03	1327.81	1.07	1327.64	1317.05	0.80	10.59	6.00	4.00	8.684	24.0	0.0	
27.03.2025	47.22	40.90	6.32	1341.74	1327.67	1.05	1327.68	1317.12	0.80	10.56	6.00	4.00	8.416	24.0	0.0	
28.03.2025	46.12	40.21	5.91	1341.31	1327.61	1.03	1327.90	1317.38	0.80	10.52	6.00	4.00	7.883	24.0	0.0	
29.03.2025	47.32	41.01	6.31	1341.83	1327.90	1.04	1327.72	1317.30	0.79	10.42	6.00	4.00	8.413	24.0	0.0	
30.03.2025	47.32	41.18	6.14	1341.71	1327.88	1.04	1327.57	1317.17	0.79	10.40	6.00	4.00	8.187	24.0	0.0	
31.03.2025	44.18	39.14	5.04	1340.25	1327.15	0.98	1327.93	1317.49	0.79	10.44	6.00	4.00	6.728	24.0	0.0	
Средние:	53.29	45.09	8.20	---	---	1.24	---	---	0.88	---	6.00	4.00	---	---	---	
Итого:	---	---	---	41688.69	41172.90	---	41133.90	40774.04	---	359.86	---	---	338.170	744.0	0.0	

Дата	V1	V2	M1	M2	Mг	Qo	ВНР	ВОС
	м3	м3	т	т	т	Гкал	ч	ч
28.02.2025	505233.17	512928.80	483642.06	494672.34	-11030.28	13416.762	40070.0	8154.0
31.03.2025	546921.86	554101.70	524775.96	535446.38	-10670.42	13754.932	40814.0	8154.0
Итого:	41688.69	41172.90	41133.90	40774.04	359.86	338.170	744.0	0.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах ГВС
(01.03.2025 0:00:00 - 31.03.2025 0:00:00)

Объект: Пермский край, Пермь г, Героев Хасана ул, д. 159 (ООО "ПРОФКОМ")
Прибор: ВКТ-7 Заводской номер: 00164154
Точка измерения: ТВ2; Ресурс: ГВС

Схема измерений: Открытая система отопления, ГВС с циркуляцией (Схема 3)

Дата	t1	t2	dt	V1	V2	M1	M2	Mг	P1	P2	Qo	Qg	ВНР	ВОС	НС
	°C	°C		м3	м3	т	т	т	кг/см2	кг/см2	Гкал	Гкал	ч	ч	
01.03.2025	58.99	46.60	12.39	117.83	79.03	115.95	78.23	37.71	7.00	7.00	3.005	1.601	24.0	0.0	
02.03.2025	59.38	46.96	12.42	123.43	78.43	121.43	77.63	43.80	7.00	7.00	3.345	1.887	24.0	0.0	
03.03.2025	59.03	46.60	12.43	112.66	79.32	110.86	78.51	32.35	7.00	7.00	2.722	1.370	24.0	0.0	
04.03.2025	58.94	46.39	12.55	111.33	79.17	109.56	78.37	31.18	7.00	7.00	2.664	1.315	24.0	0.0	
05.03.2025	59.01	46.60	12.41	113.78	78.85	111.96	78.05	33.91	7.00	7.00	2.800	1.437	24.0	0.0	
06.03.2025	59.11	46.63	12.48	112.76	78.79	110.95	77.99	32.96	7.00	7.00	2.755	1.400	24.0	0.0	
07.03.2025	59.09	46.56	12.53	112.17	78.69	110.37	77.89	32.48	7.00	7.00	2.733	1.372	24.0	0.0	
08.03.2025	59.24	46.66	12.58	112.92	78.53	111.09	77.74	33.36	7.00	7.00	2.786	1.423	24.0	0.0	
09.03.2025	59.26	46.72	12.54	117.94	78.09	116.04	77.29	38.75	7.00	7.00	3.071	1.666	24.0	0.0	
10.03.2025	59.17	46.67	12.50	112.42	78.55	110.61	77.75	32.87	7.00	7.00	2.751	1.395	24.0	0.0	
11.03.2025	59.03	46.49	12.54	111.29	78.46	109.50	77.67	31.83	7.00	7.00	2.693	1.347	24.0	0.0	
12.03.2025	58.95	46.29	12.66	111.74	78.34	109.95	77.56	32.40	7.00	7.00	2.729	1.364	24.0	0.0	
13.03.2025	59.12	46.52	12.60	112.94	78.69	111.13	77.90	33.23	7.00	7.00	2.779	1.410	24.0	0.0	
14.03.2025	59.01	46.32	12.69	110.90	78.67	109.12	77.88	31.25	7.00	7.00	2.675	1.313	24.0	0.0	
15.03.2025	59.21	46.48	12.73	113.74	78.70	111.90	77.91	34.00	7.00	7.00	2.833	1.445	24.0	0.0	
16.03.2025	59.54	46.89	12.65	122.77	77.99	120.77	77.18	43.59	7.00	7.00	3.353	1.884	24.0	0.0	
17.03.2025	59.36	46.95	12.41	116.64	78.77	114.75	77.96	36.79	7.00	7.00	2.967	1.572	24.0	0.0	
18.03.2025	59.17	46.79	12.38	112.01	79.01	110.21	78.20	32.01	7.00	7.00	2.701	1.363	24.0	0.0	
19.03.2025	58.74	47.35	11.39	107.22	69.89	105.52	69.16	36.36	7.00	7.00	2.741	1.598	24.0	0.0	
20.03.2025	59.08	49.91	9.17	109.84	74.62	108.07	73.76	34.32	7.00	7.00	2.531	1.563	24.0	0.0	
21.03.2025	59.14	47.67	11.47	115.35	78.83	113.49	78.00	35.50	7.00	7.00	2.816	1.540	24.0	0.0	
22.03.2025	59.14	47.29	11.85	115.30	80.52	113.44	79.67	33.77	7.00	7.00	2.772	1.458	24.0	0.0	
23.03.2025	59.36	47.15	12.21	123.04	81.54	121.05	80.69	40.36	7.00	7.00	3.179	1.746	24.0	0.0	
24.03.2025	59.14	46.87	12.27	114.96	81.76	113.11	80.92	32.19	7.00	7.00	2.734	1.373	24.0	0.0	
25.03.2025	59.21	46.85	12.36	114.76	81.53	112.91	80.70	32.21	7.00	7.00	2.743	1.370	24.0	0.0	
26.03.2025	59.28	47.04	12.24	117.13	81.37	115.24	80.52	34.72	7.00	7.00	2.869	1.484	24.0	0.0	
27.03.2025	59.39	47.17	12.22	118.62	81.30	116.70	80.46	36.25	7.00	7.00	2.954	1.554	24.0	0.0	
28.03.2025	59.33	47.17	12.16	114.65	81.66	112.80	80.81	31.99	7.00	7.00	2.720	1.367	24.0	0.0	
29.03.2025	59.56	47.43	12.13	119.74	81.23	117.78	80.37	37.41	7.00	7.00	3.016	1.622	24.0	0.0	
30.03.2025	59.64	47.53	12.11	123.01	80.85	121.00	80.00	41.00	7.00	7.00	3.208	1.787	24.0	0.0	
31.03.2025	58.96	47.09	11.87	115.29	80.60	113.45	79.76	33.69	7.00	7.00	2.764	1.439	24.0	0.0	
Средние:	59.18	46.96	12.22	---	---	---	---	---	7.00	7.00	---	---	---	---	
Итого:	---	---	---	3568.12	2451.75	3510.70	2426.47	1084.23	---	---	88.407	46.466	744.0	0.0	

Дата	V1	V2	M1	M2	Mг	Qo	Qg	ВНР	ВОС
	м3	м3	т	т	т	Гкал	Гкал	ч	ч
28.02.2025	936.78	16107.03	99385.02	14950.85	-15565.82	2288.080	1170.699	40150.0	8074.0
31.03.2025	4504.90	18558.79	2895.72	17377.31	-14481.60	2376.487	1217.165	40894.0	8074.0
Итого:	3568.12	2451.75	-96489.30	2426.47	1084.23	88.407	46.466	744.0	0.0

Представитель абонента

Представитель энергоснабжающей организации