

Отчет о суточных параметрах
(01.03.2025 0:00:00 - 31.03.2025 0:00:00)

Объект: Пермский край, Пермь г, Карпинского ул, д. 68 (2.2 МКД (УК "ПРОФКОМ"))
Прибор: ВКТ-7 Заводской номер: 00076925
Точка измерения: ТВ1; Ресурс: ТС

Схема измерений: Закрытая система отопления (Схема 3)

Дата	t1	t2	dt	V1	V2	%	M1	M2	%	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3		т	т		т	кг/см2	кг/см2	Гкал	ч	ч	
01.03.2025	57.59	46.48	11.11	80.41	81.46	-1.30	79.19	80.61	-1.78	-1.42	0.00	0.00	0.878	24.0	0.0	
02.03.2025	56.81	45.89	10.92	80.40	81.46	-1.31	79.20	80.68	-1.85	-1.48	0.00	0.00	0.863	24.0	0.0	
03.03.2025	57.78	46.50	11.28	80.44	81.50	-1.31	79.24	80.60	-1.70	-1.36	0.00	0.00	0.893	24.0	0.0	
04.03.2025	59.13	47.31	11.82	80.42	81.50	-1.33	79.09	80.54	-1.82	-1.45	0.00	0.00	0.930	24.0	0.0	
05.03.2025	60.54	48.32	12.22	80.43	81.51	-1.33	79.02	80.55	-1.92	-1.53	0.00	0.00	0.964	24.0	0.0	
06.03.2025	59.06	47.46	11.60	80.40	81.50	-1.36	79.12	80.54	-1.78	-1.42	0.00	0.00	0.917	24.0	0.0	
07.03.2025	58.84	47.32	11.52	80.41	81.52	-1.37	79.10	80.58	-1.85	-1.48	0.00	0.00	0.909	24.0	0.0	
08.03.2025	60.23	48.15	12.08	80.39	81.50	-1.37	79.02	80.54	-1.91	-1.52	0.00	0.00	0.952	24.0	0.0	
09.03.2025	60.75	48.50	12.25	80.41	81.54	-1.40	78.97	80.58	-2.02	-1.61	0.00	0.00	0.964	24.0	0.0	
10.03.2025	57.06	46.27	10.79	80.30	81.44	-1.41	79.04	80.64	-2.00	-1.60	0.00	0.00	0.853	24.0	0.0	
11.03.2025	55.33	44.71	10.62	77.42	78.51	-1.40	76.30	77.79	-1.93	-1.49	0.00	0.00	0.807	24.0	0.0	
12.03.2025	51.14	41.76	9.38	75.17	76.25	-1.43	74.21	75.53	-1.76	-1.32	0.00	0.00	0.694	24.0	0.0	
13.03.2025	50.10	41.05	9.05	75.16	76.26	-1.45	74.20	75.56	-1.82	-1.36	0.00	0.00	0.670	24.0	0.0	
14.03.2025	48.20	39.77	8.43	75.13	76.24	-1.47	74.31	75.72	-1.88	-1.41	0.00	0.00	0.625	24.0	0.0	
15.03.2025	46.64	38.81	7.83	75.11	76.24	-1.49	74.31	75.74	-1.91	-1.43	0.00	0.00	0.582	24.0	0.0	
16.03.2025	50.23	41.04	9.19	75.23	76.32	-1.44	74.29	75.64	-1.80	-1.35	0.00	0.00	0.680	24.0	0.0	
17.03.2025	51.16	42.25	8.91	80.05	81.19	-1.41	79.05	80.47	-1.78	-1.42	0.00	0.00	0.704	24.0	0.0	
18.03.2025	53.70	44.13	9.57	84.13	85.31	-1.39	83.03	84.48	-1.73	-1.45	0.00	0.00	0.795	24.0	0.0	
19.03.2025	57.52	46.87	10.65	84.24	85.42	-1.39	82.91	84.46	-1.85	-1.55	0.00	0.00	0.882	24.0	0.0	
20.03.2025	53.15	43.95	9.20	84.09	85.28	-1.41	82.95	84.52	-1.87	-1.57	0.00	0.00	0.763	24.0	0.0	
21.03.2025	53.23	43.84	9.39	84.09	85.26	-1.38	82.92	84.54	-1.93	-1.62	0.00	0.00	0.778	24.0	0.0	
22.03.2025	53.37	43.98	9.39	84.09	85.26	-1.38	82.89	84.54	-1.97	-1.65	0.00	0.00	0.776	24.0	0.0	
23.03.2025	51.63	42.80	8.83	84.02	85.21	-1.41	82.90	84.49	-1.90	-1.59	0.00	0.00	0.727	24.0	0.0	
24.03.2025	49.54	41.29	8.25	81.50	82.67	-1.43	80.54	81.95	-1.74	-1.41	0.00	0.00	0.661	24.0	0.0	
25.03.2025	48.54	40.43	8.11	79.45	80.58	-1.41	78.52	79.87	-1.70	-1.35	0.00	0.00	0.637	24.0	0.0	
26.03.2025	47.31	39.41	7.90	76.57	74.49	2.75	72.62	73.93	-1.79	-1.31	0.00	0.00	0.572	23.0	1.0	*
27.03.2025	46.60	38.72	7.88	74.47	75.55	-1.44	73.75	75.07	-1.77	-1.32	0.00	0.00	0.578	24.0	0.0	
28.03.2025	45.80	38.36	7.44	75.53	76.65	-1.47	74.80	76.16	-1.80	-1.36	0.00	0.00	0.556	24.0	0.0	
29.03.2025	46.93	39.21	7.72	77.08	78.18	-1.42	76.30	77.64	-1.74	-1.34	0.00	0.00	0.588	24.0	0.0	
30.03.2025	46.75	39.23	7.52	77.09	78.21	-1.44	76.34	77.70	-1.77	-1.36	0.00	0.00	0.573	24.0	0.0	
31.03.2025	44.10	37.85	6.25	82.54	83.74	-1.44	81.81	83.18	-1.66	-1.37	0.00	0.00	0.511	24.0	0.0	
Средние:	52.86	43.28	9.58	---	---	-1.27	---	---	-1.83	---	0.00	0.00	---	---	---	
Итого:	---	---	---	2466.17	2497.75	---	2429.94	2474.84	---	-44.90	---	---	23.282	743.0	1.0	

Дата	V1	V2	M1	M2	Mг	Qo	ВНР	ВОС
	м3	м3	т	т	т	Гкал	ч	ч
28.02.2025	50880.68	50841.61	50097.80	50317.03	-219.23	476.166	19794.0	2243.0
31.03.2025	53346.85	53339.36	52527.74	52791.87	-264.13	499.448	20537.0	2244.0
Итого:	2466.17	2497.75	2429.94	2474.84	-44.90	23.282	743.0	1.0

Представитель абонента

Представитель энергоснабжающей организации