

Отчет о суточных параметрах
(01.04.2025 0:00:00 - 30.04.2025 0:00:00)

Объект: Пермский край, Пермь г, Кавалерийская ул, д. 30 (2.2 МКД УК "Профком")
Прибор: ВКТ-7 Заводской номер: 00130365
Точка измерения: ТВ1; Ресурс: ТС

Схема измерений: Закрытая система отопления (Схема 3)

Дата	t1	t2	dt	V1	V2	%	M1	M2	%	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3		т	т		т	кг/см2	кг/см2	Гкал	ч	ч	
01.04.2025	42.64	37.51	5.13	49.25	49.18	0.15	48.82	48.84	-0.05	-0.02	0.00	0.00	0.250	24.0	0.0	
02.04.2025	42.87	37.61	5.26	49.02	48.95	0.15	48.59	48.61	-0.05	-0.02	0.00	0.00	0.255	24.0	0.0	
03.04.2025	44.05	38.37	5.68	48.77	48.68	0.18	48.31	48.33	-0.04	-0.02	0.00	0.00	0.274	24.0	0.0	
04.04.2025	44.96	38.89	6.07	48.62	48.53	0.20	48.15	48.17	-0.04	-0.02	0.00	0.00	0.292	24.0	0.0	
05.04.2025	43.04	37.71	5.33	49.11	49.03	0.17	48.67	48.69	-0.03	-0.02	0.00	0.00	0.259	24.0	0.0	
06.04.2025	45.36	39.27	6.09	48.71	48.61	0.22	48.23	48.24	-0.03	-0.01	0.00	0.00	0.294	24.0	0.0	
07.04.2025	45.17	39.02	6.15	48.50	48.39	0.22	48.02	48.04	-0.04	-0.02	0.00	0.00	0.295	24.0	0.0	
08.04.2025	43.71	38.09	5.62	48.95	48.86	0.18	48.49	48.52	-0.04	-0.02	0.00	0.00	0.272	24.0	0.0	
09.04.2025	41.69	36.69	5.00	32.72	32.67	0.15	32.44	32.45	-0.04	-0.01	0.00	0.00	0.162	16.0	8.0	*
10.04.2025	44.71	38.59	6.12	48.68	48.58	0.20	48.21	48.23	-0.04	-0.02	0.00	0.00	0.294	24.0	0.0	
11.04.2025	45.54	39.30	6.24	48.80	48.70	0.22	48.32	48.33	-0.03	-0.02	0.00	0.00	0.301	24.0	0.0	
12.04.2025	44.51	38.61	5.90	48.94	48.84	0.20	48.47	48.48	-0.03	-0.01	0.00	0.00	0.285	24.0	0.0	
13.04.2025	46.60	40.03	6.57	48.57	48.45	0.25	48.06	48.08	-0.03	-0.01	0.00	0.00	0.315	24.0	0.0	
14.04.2025	46.39	39.88	6.51	48.75	48.63	0.24	48.25	48.26	-0.02	-0.01	0.00	0.00	0.314	24.0	0.0	
15.04.2025	41.30	36.37	4.93	49.13	49.06	0.15	48.73	48.74	-0.03	-0.02	0.00	0.00	0.240	24.0	0.0	
16.04.2025	38.56	34.20	4.36	48.98	48.92	0.11	48.62	48.64	-0.05	-0.02	0.00	0.00	0.211	24.0	0.0	
17.04.2025	45.37	39.03	6.34	47.89	47.78	0.23	47.41	47.43	-0.03	-0.01	0.00	0.00	0.300	24.0	0.0	
18.04.2025	43.55	37.96	5.59	48.05	47.96	0.19	47.61	47.62	-0.03	-0.01	0.00	0.00	0.266	24.0	0.0	
19.04.2025	34.10	31.13	2.97	48.73	48.69	0.08	48.46	48.46	0.00	0.00	0.00	0.00	0.143	24.0	0.0	
20.04.2025	36.11	32.54	3.57	47.94	47.90	0.10	47.64	47.65	-0.02	-0.01	0.00	0.00	0.170	24.0	0.0	
21.04.2025	40.49	35.67	4.82	47.81	47.75	0.14	47.43	47.45	-0.04	-0.02	0.00	0.00	0.228	24.0	0.0	
22.04.2025	34.30	31.29	3.01	48.20	48.16	0.09	47.92	47.93	-0.01	-0.01	0.00	0.00	0.144	24.0	0.0	
23.04.2025	43.47	37.82	5.65	47.64	47.55	0.19	47.21	47.22	-0.03	-0.01	0.00	0.00	0.267	24.0	0.0	
24.04.2025	34.64	31.65	2.99	48.26	48.22	0.08	47.98	47.99	-0.02	-0.01	0.00	0.00	0.143	24.0	0.0	
25.04.2025	36.70	32.98	3.72	47.87	47.83	0.10	47.56	47.57	-0.02	-0.01	0.00	0.00	0.177	24.0	0.0	
26.04.2025	36.13	32.67	3.46	48.04	47.99	0.09	47.73	47.74	-0.03	-0.02	0.00	0.00	0.165	24.0	0.0	
27.04.2025	40.56	35.69	4.87	47.65	47.58	0.14	47.27	47.28	-0.03	-0.02	0.00	0.00	0.230	24.0	0.0	
28.04.2025	43.58	37.77	5.81	47.02	46.93	0.19	46.59	46.60	-0.03	-0.02	0.00	0.00	0.270	24.0	0.0	
29.04.2025	45.28	39.01	6.27	47.77	47.67	0.22	47.30	47.32	-0.04	-0.02	0.00	0.00	0.296	24.0	0.0	
30.04.2025	40.66	35.84	4.82	47.99	47.92	0.14	47.60	47.62	-0.04	-0.02	0.00	0.00	0.229	24.0	0.0	
Средние:	41.87	36.71	5.16	---	---	0.17	---	---	-0.03	---	0.00	0.00	---	---	---	
Итого:	---	---	---	1436.37	1433.99	---	1424.07	1424.53	---	-0.46	---	---	7.338	712.0	8.0	

Дата	V1	V2	M1	M2	Mг	Qo	ВНР	ВОС
	м3	м3	т	т	т	Гкал	ч	ч
31.03.2025	30292.15	30263.58	29896.17	29983.42	-87.25	250.800	21283.0	17.0
30.04.2025	31728.52	31697.57	31320.24	31407.95	-87.71	258.139	21995.0	25.0
Итого:	1436.37	1433.99	1424.07	1424.53	-0.46	7.338	712.0	8.0

Представитель абонента

Представитель энергоснабжающей организации