

Отчет о суточных параметрах
(01.06.2025 0:00:00 - 30.06.2025 0:00:00)

Объект: Пермский край, Пермь г, Кавалерийская ул, д. 30 (2.2 МКД УК "Профком")
Прибор: ВКТ-7 Заводской номер: 00130365
Точка измерения: ТВ1; Ресурс: ТС

Схема измерений: Закрытая система отопления (Схема 3)

Дата	t1	t2	dt	V1	V2	%	M1	M2	%	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3		т	т		т	кг/см2	кг/см2	Гкал	ч	ч	
01.06.2025	21.52	20.78	0.74	0.00	0.00	---	0.00	0.00	---	0.00	0.00	0.00	0.000	24.0	0.0	*
02.06.2025	21.78	21.09	0.69	0.00	0.00	---	0.00	0.00	---	0.00	0.00	0.00	0.000	24.0	0.0	*
03.06.2025	19.04	18.72	0.32	0.00	0.00	---	0.00	0.00	---	0.00	0.00	0.00	0.000	24.0	0.0	*
04.06.2025	18.79	18.47	0.32	0.00	0.00	---	0.00	0.00	---	0.00	0.00	0.00	0.000	24.0	0.0	*
05.06.2025	17.46	17.25	0.21	0.00	0.00	---	0.00	0.00	---	0.00	0.00	0.00	0.000	24.0	0.0	*
06.06.2025	16.44	16.26	0.18	0.00	0.00	---	0.00	0.00	---	0.00	0.00	0.00	0.000	24.0	0.0	*
07.06.2025	17.36	17.06	0.30	0.00	0.00	---	0.00	0.00	---	0.00	0.00	0.00	0.000	24.0	0.0	*
08.06.2025	18.69	18.31	0.38	0.00	0.00	---	0.00	0.00	---	0.00	0.00	0.00	0.000	24.0	0.0	*
09.06.2025	19.82	19.29	0.53	0.00	0.00	---	0.00	0.00	---	0.00	0.00	0.00	0.000	24.0	0.0	*
10.06.2025	21.58	20.82	0.76	0.00	0.00	---	0.00	0.00	---	0.00	0.00	0.00	0.000	24.0	0.0	*
11.06.2025	22.03	21.32	0.71	0.00	0.00	---	0.00	0.00	---	0.00	0.00	0.00	0.000	24.0	0.0	*
12.06.2025	21.34	20.72	0.62	0.00	0.00	---	0.00	0.00	---	0.00	0.00	0.00	0.000	24.0	0.0	*
13.06.2025	20.83	20.30	0.53	0.00	0.00	---	0.00	0.00	---	0.00	0.00	0.00	0.000	24.0	0.0	*
14.06.2025	20.55	20.06	0.49	0.00	0.00	---	0.00	0.00	---	0.00	0.00	0.00	0.000	24.0	0.0	*
15.06.2025	20.18	19.76	0.42	0.00	0.00	---	0.00	0.00	---	0.00	0.00	0.00	0.000	24.0	0.0	*
16.06.2025	19.78	19.50	0.28	0.00	0.00	---	0.00	0.00	---	0.00	0.00	0.00	0.000	24.0	0.0	*
17.06.2025	18.51	18.31	0.20	0.00	0.00	---	0.00	0.00	---	0.00	0.00	0.00	0.000	24.0	0.0	*
18.06.2025	16.41	16.33	0.08	0.00	0.00	---	0.00	0.00	---	0.00	0.00	0.00	0.000	24.0	0.0	*
19.06.2025	17.52	17.33	0.19	0.00	0.00	---	0.00	0.00	---	0.00	0.00	0.00	0.000	24.0	0.0	*
20.06.2025	17.51	17.36	0.15	0.00	0.00	---	0.00	0.00	---	0.00	0.00	0.00	0.000	24.0	0.0	*
21.06.2025	17.49	17.31	0.18	0.00	0.00	---	0.00	0.00	---	0.00	0.00	0.00	0.000	24.0	0.0	*
22.06.2025	17.16	16.99	0.17	0.00	0.00	---	0.00	0.00	---	0.00	0.00	0.00	0.000	24.0	0.0	*
23.06.2025	15.33	15.28	0.05	0.00	0.00	---	0.00	0.00	---	0.00	0.00	0.00	0.000	24.0	0.0	*
24.06.2025	15.46	15.35	0.11	0.00	0.00	---	0.00	0.00	---	0.00	0.00	0.00	0.000	24.0	0.0	*
25.06.2025	16.78	16.52	0.26	0.00	0.00	---	0.00	0.00	---	0.00	0.00	0.00	0.000	24.0	0.0	*
26.06.2025	18.55	18.13	0.42	0.00	0.00	---	0.00	0.00	---	0.00	0.00	0.00	0.000	24.0	0.0	*
27.06.2025	18.68	18.30	0.38	0.00	0.00	---	0.00	0.00	---	0.00	0.00	0.00	0.000	24.0	0.0	*
28.06.2025	18.28	18.00	0.28	0.00	0.00	---	0.00	0.00	---	0.00	0.00	0.00	0.000	24.0	0.0	*
29.06.2025	18.17	17.93	0.24	0.00	0.00	---	0.00	0.00	---	0.00	0.00	0.00	0.000	24.0	0.0	*
30.06.2025	18.17	17.91	0.26	0.00	0.00	---	0.00	0.00	---	0.00	0.00	0.00	0.000	24.0	0.0	*
Средние:	18.71	18.36	0.35	---	---	0.00	---	---	0.00	---	0.00	0.00	---	---	---	
Итого:	---	---	---	0.00	0.00	---	0.00	0.00	---	0.00	---	---	0.000	720.0	0.0	

Дата	V1	V2	M1	M2	Mг	Qo	ВНР	ВОС
	м3	м3	т	т	т	Гкал	ч	ч
31.05.2025	32325.35	32293.96	31913.09	32001.15	-88.06	260.377	22739.0	25.0
30.06.2025	32325.35	32293.96	31913.09	32001.15	-88.06	260.377	23459.0	25.0
Итого:	0.00	0.00	0.00	0.00	0.00	0.000	720.0	0.0

Представитель абонента

Представитель энергоснабжающей организации