

Отчет о суточных параметрах
(01.11.2025 0:00:00 - 30.11.2025 0:00:00)

Объект: Пермский край, Пермь г, Героев Хасана ул, д. 159 (ООО "ПРОФКОМ")
Прибор: ВКТ-7 Заводской номер: 00164154
Точка измерения: ТВ1; Ресурс: ТС

Схема измерений: Закрытая система отопления (Схема 3)

Дата	t1	t2	dt	V1	V2	%	M1	M2	%	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3		т	т		т	кг/см2	кг/см2	Гкал	ч	ч	
01.11.2025	45.83	39.93	5.90	1353.94	1338.04	1.18	1340.57	1327.90	0.95	12.67	6.00	4.00	7.941	24.0	0.0	
02.11.2025	46.38	40.27	6.11	1354.10	1338.10	1.19	1340.41	1327.79	0.95	12.62	6.00	4.00	8.226	24.0	0.0	
03.11.2025	48.27	41.31	6.96	1354.96	1338.11	1.25	1340.14	1327.23	0.97	12.91	6.00	4.00	9.361	24.0	0.0	
04.11.2025	53.05	44.76	8.29	1357.11	1338.82	1.36	1339.31	1326.08	0.99	13.23	6.00	4.00	11.142	24.0	0.0	
05.11.2025	48.65	41.83	6.82	1354.60	1337.36	1.28	1339.47	1326.17	1.00	13.30	6.00	4.00	9.163	24.0	0.0	
06.11.2025	45.52	39.50	6.02	1353.17	1336.75	1.22	1339.96	1326.82	0.99	13.14	6.00	4.00	8.098	24.0	0.0	
07.11.2025	44.87	39.10	5.77	1352.90	1336.63	1.21	1340.08	1326.89	0.99	13.19	6.00	4.00	7.772	24.0	0.0	
08.11.2025	45.98	39.91	6.07	1353.54	1337.10	1.22	1340.06	1326.97	0.98	13.09	6.00	4.00	8.166	24.0	0.0	
09.11.2025	45.50	39.53	5.97	1353.41	1336.89	1.23	1340.21	1326.94	1.00	13.27	6.00	4.00	8.030	24.0	0.0	
10.11.2025	46.48	40.23	6.25	1354.46	1328.51	1.93	1340.71	1318.31	1.68	22.40	6.00	4.00	8.429	24.0	0.0	
11.11.2025	44.70	38.87	5.83	1356.52	1299.72	4.28	1343.76	1290.39	4.05	53.37	6.00	4.00	7.869	24.0	0.0	
12.11.2025	47.89	40.97	6.92	1358.08	1300.39	4.34	1343.45	1290.01	4.06	53.44	6.00	4.00	9.328	24.0	0.0	
13.11.2025	48.48	41.53	6.95	1347.37	1304.44	3.24	1332.51	1293.72	2.95	38.79	6.00	4.00	9.288	24.0	0.0	
14.11.2025	47.89	41.19	6.70	1349.28	1329.67	1.46	1334.76	1318.93	1.19	15.83	6.00	4.00	8.977	24.0	0.0	
15.11.2025	46.41	40.18	6.23	1350.14	1331.72	1.37	1336.47	1321.47	1.13	15.00	6.00	4.00	8.367	24.0	0.0	
16.11.2025	45.24	39.21	6.03	1353.64	1335.78	1.33	1340.61	1326.01	1.10	14.60	6.00	4.00	8.115	24.0	0.0	
17.11.2025	51.12	43.09	8.03	1356.57	1337.29	1.43	1339.96	1325.48	1.09	14.48	6.00	4.00	10.794	24.0	0.0	
18.11.2025	47.02	40.51	6.51	1356.04	1334.62	1.59	1341.92	1324.19	1.33	17.73	6.00	4.00	8.776	24.0	0.0	
19.11.2025	46.66	40.11	6.55	1363.20	1312.77	3.77	1349.26	1302.73	3.51	46.53	6.00	4.00	8.868	24.0	0.0	
20.11.2025	47.37	40.67	6.70	1355.81	1336.81	1.41	1341.53	1326.31	1.14	15.22	6.00	4.00	9.024	24.0	0.0	
21.11.2025	51.91	43.75	8.16	1357.87	1337.49	1.51	1340.77	1325.34	1.16	15.43	6.00	4.00	10.983	24.0	0.0	
22.11.2025	47.59	40.92	6.67	1356.02	1336.69	1.44	1341.50	1325.99	1.16	15.51	6.00	4.00	8.978	24.0	0.0	
23.11.2025	48.02	41.17	6.85	1356.09	1336.74	1.44	1341.39	1325.97	1.16	15.42	6.00	4.00	9.222	24.0	0.0	
24.11.2025	49.56	42.09	7.47	1356.80	1336.99	1.47	1341.18	1325.72	1.16	15.46	6.00	4.00	10.056	24.0	0.0	
25.11.2025	49.15	42.14	7.01	1356.24	1336.52	1.46	1340.84	1325.21	1.17	15.63	6.00	4.00	9.428	24.0	0.0	
26.11.2025	44.86	38.87	5.99	1354.72	1335.91	1.40	1341.89	1326.32	1.17	15.57	6.00	4.00	8.078	24.0	0.0	
27.11.2025	50.92	43.14	7.78	1357.22	1336.96	1.50	1340.72	1325.14	1.17	15.58	6.00	4.00	10.473	24.0	0.0	
28.11.2025	47.66	40.94	6.72	1355.75	1336.08	1.46	1341.29	1325.43	1.19	15.86	6.00	4.00	9.046	24.0	0.0	
29.11.2025	45.38	39.31	6.07	1354.83	1335.71	1.42	1341.69	1325.89	1.18	15.80	6.00	4.00	8.176	24.0	0.0	
30.11.2025	44.54	38.63	5.91	1354.43	1335.50	1.41	1341.81	1326.03	1.18	15.78	6.00	4.00	7.959	24.0	0.0	
Средние:	47.43	40.79	6.64	---	---	1.73	---	---	1.46	---	6.00	4.00	---	---	---	
Итого:	---	---	---	40648.81	39954.11	---	40218.23	39637.38	---	580.85	---	---	268.133	720.0	0.0	

Дата	V1	V2	M1	M2	Mг	Qo	ВНР	ВОС
	м3	м3	т	т	т	Гкал	ч	ч
31.10.2025	652610.46	660483.57	629531.39	641103.10	-11571.71	14285.395	45950.0	8154.0
30.11.2025	693259.27	700437.68	669749.62	680740.48	-10990.86	14553.528	46670.0	8154.0
Итого:	40648.81	39954.11	40218.23	39637.38	580.85	268.133	720.0	0.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах ГВС
(01.11.2025 0:00:00 - 30.11.2025 0:00:00)

Объект: Пермский край, Пермь г, Героев Хасана ул, д. 159 (ООО "ПРОФКОМ")
Прибор: ВКТ-7 Заводской номер: 00164154
Точка измерения: ТВ2; Ресурс: ГВС

Схема измерений: Открытая система отопления, ГВС с циркуляцией (Схема 3)

Дата	t1	t2	dt	V1	V2	M1	M2	Mr	P1	P2	Qo	Qg	BNP	BOC	НС
	°C	°C		м3	м3	т	т	т	кг/см2	кг/см2	Гкал	Гкал	ч	ч	
01.11.2025	59.85	51.40	8.45	177.49	145.18	174.57	143.40	31.17	7.00	7.00	2.921	1.465	24.0	0.0	
02.11.2025	59.77	51.19	8.58	176.44	145.17	173.55	143.40	30.15	7.00	7.00	2.880	1.412	24.0	0.0	
03.11.2025	60.22	51.42	8.80	177.13	145.17	174.19	143.38	30.81	7.00	7.00	2.961	1.450	24.0	0.0	
04.11.2025	60.02	51.26	8.76	182.74	144.35	179.73	142.58	37.15	7.00	7.00	3.292	1.746	24.0	0.0	
05.11.2025	59.45	50.93	8.52	178.55	144.73	175.65	142.97	32.68	7.00	7.00	2.997	1.515	24.0	0.0	
06.11.2025	57.24	49.64	7.60	126.12	94.56	124.21	93.47	30.74	7.00	7.00	2.314	1.304	24.0	0.0	*
07.11.2025	58.47	51.16	7.31	144.98	112.54	142.70	111.17	31.53	7.00	7.00	2.499	1.400	24.0	0.0	*
08.11.2025	60.37	52.72	7.65	180.61	145.02	177.59	143.14	34.45	7.00	7.00	3.002	1.667	24.0	0.0	
09.11.2025	59.28	51.35	7.93	182.69	143.98	179.74	142.21	37.53	7.00	7.00	3.165	1.762	24.0	0.0	
10.11.2025	59.51	50.93	8.58	178.59	144.95	175.69	143.19	32.50	7.00	7.00	3.000	1.503	24.0	0.0	
11.11.2025	60.17	51.35	8.82	177.45	144.89	174.50	143.11	31.39	7.00	7.00	2.992	1.470	24.0	0.0	
12.11.2025	60.48	51.53	8.95	176.98	144.73	174.02	142.94	31.08	7.00	7.00	3.002	1.466	24.0	0.0	
13.11.2025	59.93	51.23	8.70	178.65	144.31	175.71	142.54	33.17	7.00	7.00	3.061	1.557	24.0	0.0	
14.11.2025	57.94	49.94	8.00	116.33	90.05	114.53	89.00	25.53	7.00	7.00	2.064	1.108	24.0	0.0	*
15.11.2025	60.05	52.94	7.11	177.21	140.23	174.28	138.40	35.88	7.00	7.00	2.959	1.742	24.0	0.0	
16.11.2025	59.28	50.63	8.65	184.76	145.06	181.78	143.33	38.45	7.00	7.00	3.325	1.783	24.0	0.0	
17.11.2025	60.53	50.97	9.56	175.84	146.00	172.89	144.24	28.65	7.00	7.00	2.969	1.335	24.0	0.0	
18.11.2025	59.29	51.00	8.29	168.73	137.52	166.00	135.85	30.15	7.00	7.00	2.762	1.406	24.0	0.0	
19.11.2025	59.92	51.93	7.99	176.81	144.28	173.90	142.47	31.43	7.00	7.00	2.863	1.488	24.0	0.0	
20.11.2025	60.06	51.36	8.70	177.55	144.51	174.62	142.73	31.88	7.00	7.00	2.995	1.497	24.0	0.0	
21.11.2025	60.82	51.46	9.36	173.52	144.16	170.58	142.38	28.20	7.00	7.00	2.906	1.328	24.0	0.0	
22.11.2025	59.54	50.65	8.89	179.94	146.26	177.01	144.51	32.50	7.00	7.00	3.055	1.503	24.0	0.0	
23.11.2025	60.64	51.73	8.91	187.16	150.24	184.01	148.37	35.64	7.00	7.00	3.304	1.700	24.0	0.0	
24.11.2025	60.49	51.34	9.15	178.01	146.62	175.02	144.82	30.20	7.00	7.00	3.000	1.420	24.0	0.0	
25.11.2025	59.91	50.89	9.02	171.34	142.69	168.52	140.96	27.56	7.00	7.00	2.783	1.275	24.0	0.0	
26.11.2025	59.53	50.59	8.94	174.00	142.16	171.17	140.47	30.70	7.00	7.00	2.929	1.419	24.0	0.0	
27.11.2025	60.58	51.35	9.23	172.40	142.45	169.50	140.70	28.80	7.00	7.00	2.897	1.356	24.0	0.0	
28.11.2025	59.85	50.78	9.07	172.60	142.35	169.76	140.64	29.12	7.00	7.00	2.871	1.351	24.0	0.0	
29.11.2025	59.41	50.56	8.85	175.87	141.70	173.02	140.01	33.01	7.00	7.00	3.034	1.524	24.0	0.0	
30.11.2025	58.09	49.68	8.41	180.79	140.73	177.98	139.11	38.87	7.00	7.00	3.233	1.752	24.0	0.0	
Средние:	59.69	51.13	8.56	---	---	---	---	---	7.00	7.00	---	---	---	---	
Итого:	---	---	---	5181.24	4186.57	5096.39	4135.48	960.90	---	---	88.032	44.699	720.0	0.0	

Дата	V1	V2	M1	M2	Mr	Qo	Qg	BNP	BOC
	м3	м3	т	т	т	Гкал	Гкал	ч	ч
31.10.2025	33468.66	41310.67	31401.22	39867.28	-8466.05	2900.396	1476.188	46030.0	8074.0
30.11.2025	38649.91	45497.24	36497.61	44002.76	-7505.15	2988.428	1520.887	46750.0	8074.0
Итого:	5181.24	4186.57	5096.39	4135.48	960.90	88.032	44.699	720.0	0.0

Представитель абонента

Представитель энергоснабжающей организации
