

Отчет о суточных параметрах
(01.11.2025 0:00:00 - 30.11.2025 0:00:00)

Объект: Пермский край, Пермь г, Кавалерийская ул, д. 30 (2.2 МКД УК "Профком")
Прибор: ВКТ-7 Заводской номер: 00130365
Точка измерения: ТВ1; Ресурс: ТС

Схема измерений: Закрытая система отопления (Схема 3)

Дата	t1	t2	dt	V1	V2	%	M1	M2	%	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3		т	т		т	кг/см2	кг/см2	Гкал	ч	ч	
01.11.2025	49.12	43.25	5.87	61.52	61.43	0.15	60.81	60.87	-0.10	-0.06	0.00	0.00	0.356	24.0	0.0	
02.11.2025	50.69	44.45	6.24	61.71	61.59	0.18	60.95	61.00	-0.09	-0.06	0.00	0.00	0.379	24.0	0.0	
03.11.2025	52.33	45.38	6.95	60.85	60.71	0.23	60.06	60.10	-0.08	-0.05	0.00	0.00	0.417	24.0	0.0	
04.11.2025	55.37	47.59	7.78	61.33	61.14	0.31	60.44	60.48	-0.06	-0.04	0.00	0.00	0.469	24.0	0.0	
05.11.2025	50.42	44.12	6.30	61.53	61.42	0.19	60.78	60.84	-0.10	-0.06	0.00	0.00	0.382	24.0	0.0	
06.11.2025	46.83	41.39	5.44	61.36	61.29	0.11	60.71	60.78	-0.10	-0.06	0.00	0.00	0.329	24.0	0.0	
07.11.2025	44.10	39.35	4.75	61.39	61.35	0.07	60.81	60.88	-0.12	-0.08	0.00	0.00	0.289	24.0	0.0	
08.11.2025	45.25	40.19	5.06	61.17	61.12	0.09	60.57	60.64	-0.12	-0.07	0.00	0.00	0.306	24.0	0.0	
09.11.2025	48.87	42.87	6.00	60.68	60.58	0.16	59.99	60.04	-0.10	-0.06	0.00	0.00	0.359	24.0	0.0	
10.11.2025	49.15	43.16	5.99	61.43	61.33	0.16	60.71	60.77	-0.10	-0.06	0.00	0.00	0.363	24.0	0.0	
11.11.2025	49.32	43.18	6.14	60.61	60.51	0.17	59.91	59.96	-0.08	-0.05	0.00	0.00	0.367	24.0	0.0	
12.11.2025	51.76	44.97	6.79	60.94	60.80	0.22	60.16	60.21	-0.08	-0.05	0.00	0.00	0.408	24.0	0.0	
13.11.2025	52.40	45.09	7.31	57.13	56.98	0.27	56.39	56.42	-0.05	-0.03	0.00	0.00	0.412	24.0	0.0	
14.11.2025	46.57	40.53	6.04	54.68	54.58	0.17	54.10	54.15	-0.08	-0.05	0.00	0.00	0.326	24.0	0.0	
15.11.2025	45.55	39.89	5.66	55.04	54.96	0.15	54.49	54.53	-0.08	-0.04	0.00	0.00	0.307	24.0	0.0	
16.11.2025	49.38	42.61	6.77	54.63	54.51	0.23	53.99	54.03	-0.06	-0.04	0.00	0.00	0.365	24.0	0.0	
17.11.2025	53.21	45.25	7.96	54.47	54.29	0.32	53.74	53.75	-0.03	-0.02	0.00	0.00	0.427	24.0	0.0	
18.11.2025	50.48	43.44	7.04	54.88	54.74	0.25	54.21	54.24	-0.05	-0.03	0.00	0.00	0.381	24.0	0.0	
19.11.2025	46.55	40.64	5.91	55.01	54.92	0.17	54.43	54.47	-0.08	-0.04	0.00	0.00	0.321	24.0	0.0	
20.11.2025	51.56	44.15	7.41	54.80	54.65	0.27	54.10	54.13	-0.05	-0.03	0.00	0.00	0.400	24.0	0.0	
21.11.2025	53.85	45.78	8.07	54.62	54.44	0.33	53.87	53.89	-0.04	-0.02	0.00	0.00	0.434	24.0	0.0	
22.11.2025	50.95	43.75	7.20	54.59	54.44	0.27	53.91	53.94	-0.05	-0.03	0.00	0.00	0.387	24.0	0.0	
23.11.2025	51.38	44.11	7.27	54.88	54.73	0.27	54.19	54.22	-0.05	-0.03	0.00	0.00	0.393	24.0	0.0	
24.11.2025	52.84	45.10	7.74	54.79	54.62	0.31	54.06	54.08	-0.04	-0.02	0.00	0.00	0.418	24.0	0.0	
25.11.2025	49.66	42.98	6.68	54.90	54.77	0.24	54.25	54.28	-0.05	-0.03	0.00	0.00	0.362	24.0	0.0	
26.11.2025	50.87	43.71	7.16	54.85	54.71	0.26	54.17	54.20	-0.06	-0.03	0.00	0.00	0.387	24.0	0.0	
27.11.2025	52.47	44.92	7.55	54.84	54.67	0.30	54.12	54.14	-0.04	-0.02	0.00	0.00	0.408	24.0	0.0	
28.11.2025	52.01	44.64	7.37	55.44	55.28	0.29	54.73	54.75	-0.04	-0.02	0.00	0.00	0.403	24.0	0.0	
29.11.2025	49.59	42.93	6.66	56.13	55.99	0.24	55.46	55.49	-0.05	-0.03	0.00	0.00	0.369	24.0	0.0	
30.11.2025	48.59	42.16	6.43	55.74	55.62	0.22	55.11	55.14	-0.06	-0.03	0.00	0.00	0.353	24.0	0.0	
Средние:	50.04	43.39	6.65	---	---	0.22	---	---	-0.07	---	0.00	0.00	---	---	---	
Итого:	---	---	---	1725.91	1722.16	---	1705.21	1706.41	---	-1.21	---	---	11.275	720.0	0.0	

Дата	V1	V2	M1	M2	Mг	Qo	ВНР	ВОС
	м3	м3	т	т	т	Гкал	ч	ч
31.10.2025	34170.69	34138.29	33741.68	33832.05	-90.38	268.781	26411.0	25.0
30.11.2025	35896.60	35860.45	35446.88	35538.47	-91.58	280.056	27131.0	25.0
Итого:	1725.91	1722.16	1705.21	1706.41	-1.21	11.275	720.0	0.0

Представитель абонента

Представитель энергоснабжающей организации