

Отчет о суточных параметрах
(01.03.2026 0:00:00 - 31.03.2026 0:00:00)

Объект: Пермский край, Пермь г, Кавалерийская ул, д. 30 (2.2 МКД УК "Профком")
Прибор: ВКТ-7 Заводской номер: 00130365
Точка измерения: ТВ1; Ресурс: ТС

Схема измерений: Закрытая система отопления (Схема 3)

Дата	t1	t2	dt	V1	V2	%	M1	M2	%	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3		т	т		т	кг/см2	кг/см2	Гкал	ч	ч	
01.03.2026	61.05	51.44	9.61	63.44	63.19	0.39	62.34	62.40	-0.09	-0.06	0.00	0.00	0.599	24.0	0.0	
02.03.2026	60.36	51.08	9.28	63.76	63.53	0.36	62.68	62.74	-0.09	-0.06	0.00	0.00	0.581	24.0	0.0	
03.03.2026	63.22	53.13	10.09	63.68	63.40	0.43	62.50	62.55	-0.09	-0.06	0.00	0.00	0.631	24.0	0.0	
04.03.2026	65.60	54.83	10.77	63.41	63.10	0.49	62.16	62.21	-0.08	-0.05	0.00	0.00	0.669	24.0	0.0	
05.03.2026	67.58	56.46	11.12	63.66	63.32	0.53	62.33	62.37	-0.07	-0.04	0.00	0.00	0.693	24.0	0.0	
06.03.2026	68.08	56.98	11.10	63.95	63.61	0.53	62.59	62.64	-0.07	-0.04	0.00	0.00	0.694	24.0	0.0	
07.03.2026	65.53	55.19	10.34	64.10	63.79	0.47	62.83	62.88	-0.07	-0.05	0.00	0.00	0.649	24.0	0.0	
08.03.2026	66.06	54.57	11.49	52.67	52.39	0.53	51.61	51.65	-0.07	-0.04	0.00	0.00	0.593	20.0	4.0	*
09.03.2026	70.96	58.52	12.44	63.48	63.07	0.65	62.03	62.06	-0.04	-0.03	0.00	0.00	0.771	24.0	0.0	
10.03.2026	70.93	58.64	12.29	63.95	63.54	0.64	62.49	62.52	-0.04	-0.03	0.00	0.00	0.767	24.0	0.0	
11.03.2026	58.94	49.94	9.00	63.78	63.55	0.36	62.73	62.79	-0.09	-0.06	0.00	0.00	0.563	24.0	0.0	
12.03.2026	50.09	43.40	6.69	63.78	63.67	0.16	63.01	63.09	-0.13	-0.08	0.00	0.00	0.421	24.0	0.0	
13.03.2026	46.36	40.66	5.70	63.75	63.70	0.08	63.09	63.19	-0.15	-0.10	0.00	0.00	0.359	24.0	0.0	
14.03.2026	44.31	39.12	5.19	64.10	64.07	0.03	63.49	63.59	-0.17	-0.11	0.00	0.00	0.329	24.0	0.0	
15.03.2026	44.50	39.56	4.94	64.91	64.89	0.03	64.28	64.39	-0.17	-0.11	0.00	0.00	0.317	24.0	0.0	
16.03.2026	45.02	39.99	5.03	64.86	64.83	0.03	64.22	64.33	-0.17	-0.11	0.00	0.00	0.323	24.0	0.0	
17.03.2026	44.63	39.76	4.87	64.74	64.73	0.03	64.12	64.23	-0.17	-0.11	0.00	0.00	0.312	24.0	0.0	
18.03.2026	44.88	39.95	4.93	65.00	64.98	0.03	64.37	64.48	-0.17	-0.11	0.00	0.00	0.317	24.0	0.0	
19.03.2026	46.06	40.93	5.13	65.11	65.08	0.05	64.44	64.55	-0.17	-0.11	0.00	0.00	0.329	24.0	0.0	
20.03.2026	45.17	40.28	4.89	64.88	64.86	0.03	64.24	64.34	-0.17	-0.11	0.00	0.00	0.314	24.0	0.0	
21.03.2026	45.83	40.65	5.18	64.60	64.57	0.05	63.94	64.05	-0.16	-0.11	0.00	0.00	0.330	24.0	0.0	
22.03.2026	44.67	39.82	4.85	64.83	64.81	0.02	64.20	64.31	-0.17	-0.11	0.00	0.00	0.311	24.0	0.0	
23.03.2026	43.88	39.20	4.68	64.84	64.83	0.01	64.23	64.35	-0.19	-0.12	0.00	0.00	0.300	24.0	0.0	
24.03.2026	45.38	40.49	4.89	66.22	66.20	0.02	65.56	65.68	-0.18	-0.12	0.00	0.00	0.320	24.0	0.0	
25.03.2026	41.39	37.35	4.04	65.37	65.39	-0.03	64.83	64.95	-0.19	-0.12	0.00	0.00	0.261	24.0	0.0	
26.03.2026	41.39	37.33	4.06	65.53	65.55	-0.03	64.98	65.10	-0.18	-0.12	0.00	0.00	0.263	24.0	0.0	
27.03.2026	43.54	39.10	4.44	66.30	66.30	-0.01	65.69	65.81	-0.19	-0.12	0.00	0.00	0.291	24.0	0.0	
28.03.2026	43.07	39.14	3.93	66.68	66.69	-0.03	66.07	66.19	-0.18	-0.12	0.00	0.00	0.259	24.0	0.0	
29.03.2026	36.73	33.79	2.94	65.70	65.76	-0.09	65.27	65.39	-0.19	-0.12	0.00	0.00	0.192	24.0	0.0	
30.03.2026	36.74	33.78	2.96	65.76	65.82	-0.09	65.33	65.45	-0.19	-0.12	0.00	0.00	0.193	24.0	0.0	
31.03.2026	37.40	34.29	3.11	65.84	65.90	-0.09	65.39	65.52	-0.20	-0.13	0.00	0.00	0.203	24.0	0.0	
Средние:	51.27	44.50	6.77	---	---	0.18	---	---	-0.14	---	0.00	0.00	---	---	---	
Итого:	---	---	---	1992.62	1989.12	---	1967.03	1969.77	---	-2.74	---	---	13.151	740.0	4.0	

Дата	V1	V2	M1	M2	Mг	Qo	ВНР	ВОС
	м3	м3	т	т	т	Гкал	ч	ч
28.02.2026	41474.66	41408.91	40918.90	41010.30	-91.40	335.432	29289.0	27.0
31.03.2026	43467.27	43398.03	42885.93	42980.07	-94.14	348.584	30029.0	31.0
Итого:	1992.62	1989.12	1967.03	1969.77	-2.74	13.151	740.0	4.0

Представитель абонента

Представитель энергоснабжающей организации