

Отчет о суточных параметрах
(01.03.2026 0:00:00 - 31.03.2026 0:00:00)

Объект: Пермский край, Пермь г, Нефтяников ул, д. 8 (2.1 МКД УК "ПРОФКОМ")
Прибор: ВКТ-7 Заводской номер: 00115026
Точка измерения: ТВ1; Ресурс: TC

Схема измерений: Закрытая система отопления (Схема 3)

Дата	t1	t2	dt	V1	V2	%	M1	M2	%	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3		т	т		т	кг/см2	кг/см2	Гкал	ч	ч	
01.03.2026	90.35	50.55	39.80	13.89	13.58	2.25	13.40	13.41	-0.07	-0.01	0.00	0.00	0.534	24.0	0.0	
02.03.2026	88.44	50.52	37.92	14.10	13.80	2.14	13.62	13.63	-0.02	0.00	0.00	0.00	0.517	24.0	0.0	
03.03.2026	93.77	52.26	41.51	14.05	13.70	2.52	13.52	13.52	0.03	0.00	0.00	0.00	0.562	24.0	0.0	
04.03.2026	98.22	53.41	44.81	13.93	13.55	2.82	13.38	13.36	0.09	0.01	0.00	0.00	0.600	24.0	0.0	
05.03.2026	100.13	54.74	45.39	14.36	13.95	2.92	13.76	13.75	0.11	0.02	0.00	0.00	0.626	24.0	0.0	
06.03.2026	100.41	56.17	44.24	15.11	14.69	2.83	14.48	14.48	0.03	0.00	0.00	0.00	0.642	24.0	0.0	
07.03.2026	97.72	55.99	41.73	15.65	15.26	2.57	15.02	15.03	-0.03	-0.01	0.00	0.00	0.628	24.0	0.0	
08.03.2026	99.09	56.33	42.76	15.52	15.11	2.66	14.88	14.88	-0.03	-0.01	0.00	0.00	0.638	24.0	0.0	
09.03.2026	106.72	58.15	48.57	15.30	14.82	3.18	14.59	14.59	-0.01	0.00	0.00	0.00	0.710	24.0	0.0	
10.03.2026	105.81	58.79	47.02	15.89	15.41	3.06	15.16	15.15	0.03	0.00	0.00	0.00	0.715	24.0	0.0	
11.03.2026	88.59	52.22	36.37	15.35	15.04	1.99	14.83	14.85	-0.13	-0.02	0.00	0.00	0.539	24.0	0.0	
12.03.2026	74.79	46.42	28.37	14.88	14.70	1.21	14.51	14.55	-0.28	-0.04	0.00	0.00	0.411	24.0	0.0	
13.03.2026	71.69	44.03	27.66	13.69	13.55	1.09	13.38	13.42	-0.31	-0.04	0.00	0.00	0.370	24.0	0.0	
14.03.2026	75.30	46.78	28.52	14.60	14.43	1.19	14.23	14.27	-0.32	-0.05	0.00	0.00	0.406	24.0	0.0	
15.03.2026	73.08	46.66	26.42	14.68	14.53	1.03	14.33	14.38	-0.34	-0.05	0.00	0.00	0.378	24.0	0.0	
16.03.2026	71.69	44.94	26.75	13.65	13.52	0.99	13.33	13.39	-0.40	-0.05	0.00	0.00	0.356	24.0	0.0	
17.03.2026	71.82	44.53	27.29	12.92	12.80	0.97	12.62	12.68	-0.41	-0.05	0.00	0.00	0.344	24.0	0.0	
18.03.2026	70.14	43.56	26.58	12.54	12.44	0.84	12.26	12.32	-0.48	-0.06	0.00	0.00	0.326	24.0	0.0	
19.03.2026	71.26	44.75	26.51	13.42	13.31	0.82	13.11	13.18	-0.54	-0.07	0.00	0.00	0.347	24.0	0.0	
20.03.2026	71.15	44.06	27.09	13.05	12.94	0.85	12.75	12.82	-0.53	-0.07	0.00	0.00	0.345	24.0	0.0	
21.03.2026	69.13	41.17	27.96	11.35	11.26	0.82	11.11	11.16	-0.49	-0.05	0.00	0.00	0.310	24.0	0.0	
22.03.2026	69.68	41.90	27.78	11.79	11.69	0.83	11.53	11.60	-0.55	-0.06	0.00	0.00	0.320	24.0	0.0	
23.03.2026	69.21	42.38	26.83	12.11	12.01	0.79	11.84	11.91	-0.56	-0.07	0.00	0.00	0.317	24.0	0.0	
24.03.2026	69.34	43.26	26.08	12.48	12.38	0.75	12.21	12.27	-0.54	-0.07	0.00	0.00	0.318	24.0	0.0	
25.03.2026	67.62	42.29	25.33	12.10	12.03	0.65	11.85	11.92	-0.61	-0.07	0.00	0.00	0.300	24.0	0.0	
26.03.2026	68.29	42.66	25.63	12.11	12.03	0.67	11.85	11.92	-0.60	-0.07	0.00	0.00	0.303	24.0	0.0	
27.03.2026	68.23	42.76	25.47	12.04	11.96	0.68	11.78	11.85	-0.56	-0.07	0.00	0.00	0.300	24.0	0.0	
28.03.2026	69.55	43.72	25.83	12.27	12.19	0.67	12.00	12.07	-0.62	-0.08	0.00	0.00	0.309	24.0	0.0	
29.03.2026	68.17	42.43	25.74	11.59	11.52	0.65	11.35	11.41	-0.61	-0.07	0.00	0.00	0.292	24.0	0.0	
30.03.2026	68.23	42.97	25.26	12.21	12.13	0.61	11.95	12.02	-0.62	-0.07	0.00	0.00	0.301	24.0	0.0	
31.03.2026	68.87	43.98	24.89	12.74	12.66	0.62	12.46	12.54	-0.59	-0.07	0.00	0.00	0.310	24.0	0.0	
Средние:	79.89	47.56	32.33	---	---	1.47	---	---	-0.32	---	0.00	0.00	---	---	---	
Итого:	---	---	---	419.35	412.94	---	407.08	408.32	---	-1.23	---	---	13.374	744.0	0.0	

Дата	V1	V2	M1	M2	Mг	Qo	ВНР	ВОС
	м3	м3	т	т	т	Гкал	ч	ч
28.02.2026	8275.46	8201.10	8027.89	8107.20	-79.31	258.607	23680.0	2154.0
31.03.2026	8694.81	8614.04	8434.97	8515.52	-80.54	271.980	24424.0	2154.0
Итого:	419.35	412.94	407.08	408.32	-1.23	13.374	744.0	0.0

Представитель абонента

Представитель энергоснабжающей организации
