

Отчет о суточных параметрах
(01.04.2026 0:00:00 - 30.04.2026 0:00:00)

Объект: Пермский край, Пермь г, Кавалерийская ул, д. 30 (2.2 МКД УК "Профком")
Прибор: ВКТ-7 Заводской номер: 00130365
Точка измерения: ТВ1; Ресурс: ТС

Схема измерений: Закрытая система отопления (Схема 3)

Дата	t1	t2	dt	V1	V2	%	M1	M2	%	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3		т	т		т	кг/см2	кг/см2	Гкал	ч	ч	
01.04.2026	37.90	34.81	3.09	66.21	66.26	-0.08	65.74	65.87	-0.19	-0.13	0.00	0.00	0.203	24.0	0.0	
02.04.2026	35.86	33.26	2.60	66.38	66.45	-0.10	65.96	66.09	-0.19	-0.12	0.00	0.00	0.171	24.0	0.0	
03.04.2026	33.31	31.17	2.14	65.94	66.01	-0.10	65.58	65.70	-0.18	-0.12	0.00	0.00	0.140	24.0	0.0	
04.04.2026	34.94	32.13	2.81	64.48	64.53	-0.08	64.09	64.20	-0.17	-0.11	0.00	0.00	0.180	24.0	0.0	
05.04.2026	39.08	35.43	3.65	65.30	65.34	-0.06	64.81	64.94	-0.19	-0.13	0.00	0.00	0.236	24.0	0.0	
06.04.2026	40.10	36.25	3.85	65.26	65.30	-0.05	64.75	64.88	-0.19	-0.12	0.00	0.00	0.249	24.0	0.0	
07.04.2026	39.62	35.77	3.85	64.90	64.94	-0.06	64.40	64.53	-0.20	-0.13	0.00	0.00	0.247	24.0	0.0	
08.04.2026	39.66	35.84	3.82	65.54	65.57	-0.06	65.03	65.16	-0.20	-0.13	0.00	0.00	0.248	24.0	0.0	
09.04.2026	40.23	36.19	4.04	64.69	64.72	-0.04	64.18	64.30	-0.19	-0.12	0.00	0.00	0.259	24.0	0.0	
10.04.2026	37.89	33.94	3.95	64.05	64.08	-0.04	63.60	63.72	-0.18	-0.11	0.00	0.00	0.251	24.0	0.0	
11.04.2026	38.02	34.08	3.94	64.06	64.09	-0.04	63.61	63.73	-0.18	-0.12	0.00	0.00	0.250	24.0	0.0	
12.04.2026	41.42	36.90	4.52	64.96	64.97	-0.02	64.42	64.54	-0.19	-0.12	0.00	0.00	0.291	24.0	0.0	
13.04.2026	41.39	37.19	4.20	65.92	65.95	-0.04	65.37	65.51	-0.21	-0.14	0.00	0.00	0.274	24.0	0.0	
14.04.2026	41.75	37.68	4.07	66.49	66.52	-0.05	65.93	66.07	-0.20	-0.14	0.00	0.00	0.268	24.0	0.0	
15.04.2026	41.56	37.55	4.01	65.71	65.74	-0.05	65.16	65.29	-0.20	-0.13	0.00	0.00	0.261	24.0	0.0	
16.04.2026	42.41	38.24	4.17	65.83	65.86	-0.04	65.26	65.39	-0.20	-0.13	0.00	0.00	0.271	24.0	0.0	
17.04.2026	41.90	37.97	3.93	66.24	66.28	-0.05	65.68	65.81	-0.20	-0.13	0.00	0.00	0.257	24.0	0.0	
18.04.2026	42.60	38.58	4.02	66.51	66.54	-0.04	65.92	66.06	-0.20	-0.13	0.00	0.00	0.264	24.0	0.0	
19.04.2026	41.38	37.50	3.88	65.24	65.28	-0.06	64.70	64.83	-0.20	-0.13	0.00	0.00	0.250	24.0	0.0	
20.04.2026	41.36	37.05	4.31	64.15	64.17	-0.03	63.62	63.74	-0.20	-0.13	0.00	0.00	0.274	24.0	0.0	
21.04.2026	44.93	39.70	5.23	64.21	64.20	0.02	63.58	63.71	-0.19	-0.12	0.00	0.00	0.332	24.0	0.0	
22.04.2026	44.42	39.48	4.94	64.89	64.89	0.00	64.27	64.40	-0.20	-0.13	0.00	0.00	0.317	24.0	0.0	
23.04.2026	44.16	39.30	4.86	65.33	65.33	0.00	64.72	64.85	-0.20	-0.13	0.00	0.00	0.314	24.0	0.0	
24.04.2026	46.56	41.42	5.14	66.54	66.52	0.02	65.85	65.97	-0.18	-0.12	0.00	0.00	0.338	24.0	0.0	
25.04.2026	45.11	40.35	4.76	66.09	66.09	0.00	65.44	65.56	-0.19	-0.13	0.00	0.00	0.311	24.0	0.0	
26.04.2026	44.99	40.22	4.77	66.22	66.22	0.00	65.57	65.70	-0.20	-0.13	0.00	0.00	0.312	24.0	0.0	
27.04.2026	40.84	37.03	3.81	66.43	66.47	-0.05	65.89	66.02	-0.20	-0.13	0.00	0.00	0.251	24.0	0.0	
28.04.2026	38.61	35.02	3.59	65.65	65.70	-0.08	65.17	65.31	-0.21	-0.13	0.00	0.00	0.233	24.0	0.0	
29.04.2026	40.25	36.38	3.87	65.50	65.54	-0.07	64.98	65.12	-0.21	-0.13	0.00	0.00	0.251	24.0	0.0	
30.04.2026	40.70	36.74	3.96	65.70	65.75	-0.07	65.17	65.31	-0.22	-0.14	0.00	0.00	0.258	24.0	0.0	
Средние:	40.77	36.77	3.99	---	---	-0.04	---	---	-0.19	---	0.00	0.00	---	---	---	
Итого:	---	---	---	1964.41	1965.28	---	1948.46	1952.26	---	-3.80	---	---	7.760	720.0	0.0	

Дата	V1	V2	M1	M2	Mг	Qo	ВНР	ВОС
	м3	м3	т	т	т	Гкал	ч	ч
31.03.2026	43467.27	43398.03	42885.93	42980.07	-94.14	348.584	30029.0	31.0
30.04.2026	45431.68	45363.31	44834.39	44932.34	-97.94	356.344	30749.0	31.0
Итого:	1964.41	1965.28	1948.46	1952.26	-3.80	7.760	720.0	0.0

Представитель абонента

Представитель энергоснабжающей организации
