

Отчет о суточных параметрах  
(01.04.2026 0:00:00 - 30.04.2026 0:00:00)

Объект: Пермский край, Пермь г, Нефтяников ул, д. 8 (2.1 МКД УК "ПРОФКОМ")  
Прибор: ВКТ-7 Заводской номер: 00115026  
Точка измерения: ТВ1; Ресурс: ТС

Схема измерений: Закрытая система отопления (Схема 3)

| Дата       | t1    | t2    | dt    | V1     | V2     | %    | M1     | M2     | %     | Mг    | P1     | P2     | Qo    | ВНР   | ВОС  | НС |
|------------|-------|-------|-------|--------|--------|------|--------|--------|-------|-------|--------|--------|-------|-------|------|----|
|            | °C    | °C    | °C    | м3     | м3     |      | т      | т      |       | т     | кг/см2 | кг/см2 | Гкал  | ч     | ч    |    |
| 01.04.2026 | 69.28 | 44.28 | 25.00 | 12.94  | 12.86  | 0.61 | 12.65  | 12.74  | -0.65 | -0.08 | 0.00   | 0.00   | 0.316 | 24.0  | 0.0  |    |
| 02.04.2026 | 70.66 | 46.09 | 24.57 | 13.97  | 13.87  | 0.71 | 13.65  | 13.73  | -0.53 | -0.07 | 0.00   | 0.00   | 0.335 | 24.0  | 0.0  |    |
| 03.04.2026 | 71.13 | 46.71 | 24.42 | 11.45  | 11.01  | 3.84 | 10.84  | 10.90  | -0.54 | -0.06 | 0.00   | 0.00   | 0.264 | 19.0  | 5.0  | *  |
| 04.04.2026 | 67.82 | 41.53 | 26.29 | 0.00   | ---    | ---  | ---    | ---    | ---   | 0.00  | 0.00   | ---    | ---   | 0.0   | 24.0 | *  |
| 05.04.2026 | 68.10 | 40.44 | 27.66 | 0.00   | ---    | ---  | ---    | ---    | ---   | 0.00  | 0.00   | ---    | ---   | 0.0   | 24.0 | *  |
| 06.04.2026 | 68.47 | 40.74 | 27.73 | 6.74   | 6.58   | 2.31 | 6.49   | 6.53   | -0.57 | -0.04 | 0.00   | 0.00   | 0.180 | 15.0  | 9.0  | *  |
| 07.04.2026 | 67.77 | 40.07 | 27.70 | 10.63  | 10.56  | 0.71 | 10.41  | 10.48  | -0.68 | -0.07 | 0.00   | 0.00   | 0.288 | 24.0  | 0.0  |    |
| 08.04.2026 | 70.19 | 43.26 | 26.93 | 12.40  | 12.31  | 0.74 | 12.12  | 12.20  | -0.61 | -0.07 | 0.00   | 0.00   | 0.326 | 24.0  | 0.0  |    |
| 09.04.2026 | 67.54 | 39.73 | 27.81 | 10.63  | 10.56  | 0.69 | 10.41  | 10.48  | -0.68 | -0.07 | 0.00   | 0.00   | 0.289 | 24.0  | 0.0  |    |
| 10.04.2026 | 68.49 | 37.61 | 30.88 | 9.87   | 9.79   | 0.82 | 9.66   | 9.72   | -0.57 | -0.06 | 0.00   | 0.00   | 0.298 | 24.0  | 0.0  |    |
| 11.04.2026 | 69.17 | 37.48 | 31.69 | 9.55   | 9.47   | 0.86 | 9.34   | 9.40   | -0.63 | -0.06 | 0.00   | 0.00   | 0.296 | 24.0  | 0.0  |    |
| 12.04.2026 | 70.27 | 40.31 | 29.96 | 10.87  | 10.77  | 0.88 | 10.62  | 10.68  | -0.57 | -0.06 | 0.00   | 0.00   | 0.318 | 24.0  | 0.0  |    |
| 13.04.2026 | 68.99 | 40.98 | 28.01 | 11.48  | 11.39  | 0.77 | 11.23  | 11.30  | -0.59 | -0.07 | 0.00   | 0.00   | 0.314 | 24.0  | 0.0  |    |
| 14.04.2026 | 69.43 | 43.05 | 26.38 | 12.43  | 12.34  | 0.69 | 12.15  | 12.23  | -0.64 | -0.08 | 0.00   | 0.00   | 0.320 | 24.0  | 0.0  |    |
| 15.04.2026 | 68.79 | 41.13 | 27.66 | 11.18  | 11.10  | 0.72 | 10.94  | 11.00  | -0.61 | -0.07 | 0.00   | 0.00   | 0.302 | 24.0  | 0.0  |    |
| 16.04.2026 | 68.77 | 40.43 | 28.34 | 10.67  | 10.59  | 0.72 | 10.44  | 10.50  | -0.61 | -0.06 | 0.00   | 0.00   | 0.295 | 24.0  | 0.0  |    |
| 17.04.2026 | 68.14 | 41.50 | 26.64 | 11.36  | 11.29  | 0.64 | 11.12  | 11.19  | -0.69 | -0.08 | 0.00   | 0.00   | 0.296 | 24.0  | 0.0  |    |
| 18.04.2026 | 68.93 | 42.69 | 26.24 | 11.76  | 11.68  | 0.67 | 11.50  | 11.58  | -0.66 | -0.08 | 0.00   | 0.00   | 0.302 | 24.0  | 0.0  |    |
| 19.04.2026 | 68.69 | 41.63 | 27.06 | 10.93  | 10.86  | 0.67 | 10.70  | 10.77  | -0.64 | -0.07 | 0.00   | 0.00   | 0.289 | 24.0  | 0.0  |    |
| 20.04.2026 | 68.94 | 39.58 | 29.36 | 10.33  | 10.25  | 0.74 | 10.11  | 10.17  | -0.65 | -0.07 | 0.00   | 0.00   | 0.296 | 24.0  | 0.0  |    |
| 21.04.2026 | 71.88 | 40.29 | 31.59 | 10.74  | 10.64  | 0.94 | 10.49  | 10.56  | -0.65 | -0.07 | 0.00   | 0.00   | 0.331 | 24.0  | 0.0  |    |
| 22.04.2026 | 70.16 | 40.40 | 29.76 | 10.79  | 10.70  | 0.82 | 10.55  | 10.62  | -0.70 | -0.07 | 0.00   | 0.00   | 0.313 | 24.0  | 0.0  |    |
| 23.04.2026 | 69.46 | 40.17 | 29.29 | 10.86  | 10.78  | 0.77 | 10.62  | 10.69  | -0.65 | -0.07 | 0.00   | 0.00   | 0.311 | 24.0  | 0.0  |    |
| 24.04.2026 | 69.04 | 41.92 | 27.12 | 11.80  | 11.72  | 0.70 | 11.54  | 11.62  | -0.63 | -0.07 | 0.00   | 0.00   | 0.313 | 24.0  | 0.0  |    |
| 25.04.2026 | 68.34 | 41.06 | 27.28 | 11.13  | 11.06  | 0.64 | 10.89  | 10.96  | -0.68 | -0.07 | 0.00   | 0.00   | 0.297 | 24.0  | 0.0  |    |
| 26.04.2026 | 68.37 | 40.99 | 27.38 | 11.10  | 11.03  | 0.64 | 10.86  | 10.93  | -0.67 | -0.07 | 0.00   | 0.00   | 0.297 | 24.0  | 0.0  |    |
| 27.04.2026 | 69.34 | 43.39 | 25.95 | 12.75  | 12.67  | 0.61 | 12.47  | 12.56  | -0.69 | -0.09 | 0.00   | 0.00   | 0.323 | 24.0  | 0.0  |    |
| 28.04.2026 | 68.56 | 43.02 | 25.54 | 12.47  | 12.40  | 0.59 | 12.20  | 12.29  | -0.68 | -0.08 | 0.00   | 0.00   | 0.311 | 24.0  | 0.0  |    |
| 29.04.2026 | 68.76 | 43.60 | 25.16 | 12.99  | 12.35  | 5.01 | 12.16  | 12.24  | -0.68 | -0.08 | 0.00   | 0.00   | 0.306 | 23.0  | 1.0  | *  |
| 30.04.2026 | 69.23 | 43.99 | 25.24 | 13.15  | 13.08  | 0.56 | 12.86  | 12.95  | -0.72 | -0.09 | 0.00   | 0.00   | 0.324 | 24.0  | 0.0  |    |
| Средние:   | 69.09 | 41.60 | 27.49 | ---    | ---    | 1.04 | ---    | ---    | -0.64 | ---   | 0.00   | 0.00   | ---   | ---   | ---  |    |
| Итого:     | ---   | ---   | ---   | 316.94 | 313.69 | ---  | 309.03 | 311.01 | ---   | -1.98 | ---    | ---    | 8.450 | 657.0 | 63.0 |    |

| Дата       | V1      | V2      | M1      | M2      | Mг     | Qo      | ВНР     | ВОС    |
|------------|---------|---------|---------|---------|--------|---------|---------|--------|
|            | м3      | м3      | т       | т       | т      | Гкал    | ч       | ч      |
| 31.03.2026 | 8694.81 | 8614.04 | 8434.97 | 8515.52 | -80.54 | 271.980 | 24424.0 | 2154.0 |
| 30.04.2026 | 9011.74 | 8927.73 | 8744.01 | 8826.53 | -82.52 | 280.430 | 25081.0 | 2217.0 |
| Итого:     | 316.94  | 313.69  | 309.03  | 311.01  | -1.98  | 8.450   | 657.0   | 63.0   |

Представитель абонента

\_\_\_\_\_

Представитель энергоснабжающей организации

\_\_\_\_\_